
RESRAD-BUILD Verification

**Environmental Assessment Division
Argonne National Laboratory**

Operated by The University of Chicago,
under Contract W-31-109-Eng-38, for the

United States Department of Energy



Argonne National Laboratory, with facilities in the states of Illinois and Idaho, is owned by the United States Government and operated by The University of Chicago under the provisions of a contract with the U.S. Department of Energy.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor The University of Chicago, nor any of their employees or officers, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of document authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, Argonne National Laboratory, or The University of Chicago.

Available electronically at <http://www.doe.gov/bridge>

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from:

U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: (865) 576-8401
fax: (865) 576-5728
email: reports@adonis.osti.gov

ANL/EAD/TM-115

RESRAD-BUILD Verification

by S. Kamboj, C. Yu, B.M. Biwer, and T. Klett

Environmental Assessment Division
Argonne National Laboratory, 9700 South Cass Avenue, Argonne, Illinois 60439

October 2001

Work sponsored by U.S. Department of Energy, Assistant Secretary for Environment, Safety, and Health, Office of Environmental Policy and Guidance, Assistant Secretary for Environmental Management, Office of Site Closure

NOTICE

This technical memorandum is an information product of Argonne's Environmental Assessment Division (EAD). It presents results of ongoing work or work that is more limited in scope and depth than that described in formal reports issued by EAD. This memorandum has undergone internal technical review and has been edited according to EAD's quality assurance requirements. In contrast to a formal technical report, this memorandum has not been externally peer reviewed.

For more information on the division's scientific and engineering activities, contact:

Director, Environmental Assessment Division
Argonne National Laboratory
Argonne, Illinois 60439
Telephone (630) 252-3107
email: ead@anl.gov

Publishing support services were provided by Argonne's Information and Publishing Division (for more information, see IPD's home page: <http://www.ipd.anl.gov>).



This report is printed on recycled paper.

CONTENTS

NOTATION	vii
ABSTRACT	1
1 INTRODUCTION.....	1
2 PARAMETER VERIFICATION.....	5
3 SOURCE INJECTION RATE	11
4 AIR CONCENTRATION AND PARTICULATE DEPOSITION	15
5 RADON PATHWAY MODEL	25
5.1 Radon Injection Rate.....	26
5.2 Radon Progeny Concentration	30
6 TRITIUM MODEL FOR VOLUME SOURCE	37
7 EXTERNAL EXPOSURE MODEL.....	45
8 DIFFERENT PATHWAY DOSES.....	53
8.1 Submersion Pathway.....	53
8.2 Inadvertent Ingestion Directly from the Source.....	55
8.3 Inadvertent Ingestion of Deposited Materials	58
8.4 Dose from Inhalation of Airborne Radioactive Particulates	59
8.5 Dose from Inhalation of Aerosol Indoor Radon Progeny	63
8.6 Direct External Exposure	63
8.7 External Exposure to Deposited Materials.....	64
8.8 Tritium Volume Source.....	67
8.9 Total Dose at a Receptor Location.....	69
9 TIME DEPENDENCE IN DOSE CALCULATIONS.....	73
9.1 Time Integration in RESRAD-BUILD	73
9.2 Time Dependence of Source Characteristics in Dose	74
10 CONCLUSIONS.....	77
11 VERIFICATION LIMITATIONS AND SUGGESTIONS FOR IMPROVEMENT	81
12 REFERENCES.....	83

CONTENTS (Cont.)

APPENDIX: RESRAD-BUILD INPUT-OUTPUT TEST CASE FILES
AND DIAG.OUT AND SUMMARY REPORTS 85

TABLES

2.1 Errors Noted in nucdef.dat File 5

2.2 Parameters and Parameter Values Used in RESRAD-BUILD Verification 7

2.3 Cases Used in RESRAD-BUILD Verification 9

3.1 Comparison of RESRAD-BUILD and Spreadsheet Values
for Source Injection Rate 13

4.1 RESRAD-BUILD and Spreadsheet Air Concentration Values
for the One-Room Air Quality Model 18

4.2 RESRAD-BUILD and Spreadsheet Air Concentration Values
for the Two-Room Air Quality Model..... 22

5.1 RESRAD-BUILD and Spreadsheet Injection Rates for Ra-226 and Th-228
Point and Volume Sources for Three Sets of Input Parameters 30

5.2 RESRAD-BUILD and Spreadsheet Air Concentrations for Ra-226
and Th-228 and Their Progeny for Three Sets of Input Parameters 32

7.1 Point Source Dose Comparison between RESRAD-BUILD and MCNP 49

7.2 Line Source Dose Comparison between RESRAD-BUILD and MCNP 50

7.3 Area Source Dose Comparison between RESRAD-BUILD and MCNP 50

7.4 Volume Source Dose Comparison between RESRAD-BUILD and MCNP..... 51

7.5 Direct External Exposure Pathway Dose Comparison
between RESRAD-BUILD and MCNP Using Default Parameters 51

8.1 RESRAD-BUILD and Spreadsheet Submersion Pathway Dose Values
for Three Sets of Input Parameters 55

TABLES (Cont.)

8.2	RESRAD-BUILD and Spreadsheet Direct Inadvertent Ingestion Pathway Dose Values for Three Sets of Input Parameters	58
8.3	RESRAD-BUILD and Spreadsheet Dose Values for the Inadvertent Ingestion of Deposited Material for Three Sets of Input Parameters	61
8.4	RESRAD-BUILD and Spreadsheet Inhalation Pathway Dose Values for Three Sets of Input Parameters	63
8.5	RESRAD-BUILD and Spreadsheet Radon Inhalation Pathway Dose Values for Ra-226 and Th-228 Sources for Three Sets of Input Parameters.....	64
8.6	RESRAD-BUILD and Spreadsheet Direct External Exposure Pathway Dose Values for Three Sets of Input Parameters	67
8.7	RESRAD-BUILD and Spreadsheet Dose Values from the External Exposure of Deposited Material for Three Sets of Input Parameters	69
8.8	RESRAD-BUILD and Spreadsheet Inhalation and Ingestion Pathway Dose Values for the Tritium Volume Source for Three Sets of Input Parameters	71
8.9	Receptor Dose for Different Exposure Times for the Ra-228 Volume Source	72
9.1	Calculated Dose for the Ra-228 Volume Source with Default Parameters.....	73
9.2	Time Dependence of Source Emission Rate and Effect on Estimated Data	75
9.3	Calculated Radionuclide Concentrations at Different Times in the RESRAD-BUILD and RESRAD Codes for an Initial Parent Concentration of 1 pCi/g	76
10.1	Conclusions on Types of Calculations Investigated.....	78

FIGURES

3.1	Source Injection Rate Calculations for Volume, Surface, Line, and Point Sources.....	14
4.1	Calculated Air Concentrations for Volume, Surface, Line, and Point Sources for the One-Room Air Quality Model	17

FIGURES (Cont.)

4.2	Calculated Air Concentrations for the Volume Source for the Two-Room Air Quality Model.....	19
4.3	Calculated Air Concentrations for Point, Line, and Surface Sources for the Two-Room Air Quality Model.....	20
4.4	In-between Calculations for the Two-Room Air Quality Model.....	21
4.5	Calculated Surface Concentration from Deposition.....	24
5.1	Radon Flux Calculations for a Volume Source.....	28
5.2	Injection Rates for Rn-222 and Rn-220 for a Point and Volume Source.....	31
5.3	Air Concentrations for Ra-226 and Th-228 Progeny for a Point Source.....	33
6.1	Tritium Model Intermediate Calculations for the Injection Rate from Vaporization and the Average Release Rate from the Tritium Volume Source from Volatization.....	42
8.1	Air Submersion Pathway Dose Calculations.....	54
8.2	Inadvertent Ingestion Pathway Dose Directly from the Source.....	57
8.3	Inadvertent Ingestion Pathway Dose Directly from Materials Deposited on Surfaces.....	60
8.4	Inhalation Pathway Dose Calculations.....	62
8.5	Radon Pathway Dose Calculations.....	65
8.6	Direct External Exposure Pathway Doses from a Volume and Surface Source of a Large Area.....	66
8.7	External Exposure from Deposited Materials.....	68
8.8	Inhalation and Ingestion Pathway Doses for a Tritium Volume Source for the Default Parameter Set.....	70
8.9	Estimated Dose with and without Time Integration.....	72

NOTATION

The following is a list of the acronyms, initialisms, and abbreviations (including units of measure) used in this document.

ACRONYMS, INITIALISMS, AND ABBREVIATIONS

DCF	dose conversion factor
FGR	Federal Guidance Report
G-P	geometric progression
HTO	tritiated water
MCNP	Monte Carlo N-particle
WL	working level
WLM	working level month

UNITS OF MEASURE

atm	atmosphere(s)
cm	centimeter(s)
cm ²	square centimeter(s)
cm ³	cubic centimeter(s)
d	day(s)
g	gram(s)
h	hour(s)
K	kelvin(s)
kg	kilogram(s)
m	meter(s)
m ²	square meter(s)
m ³	cubic meter(s)
mol	mole(s)
mrem	millirem(s)
pCi	picocurie(s)
s	second(s)
yr	year(s)

RESRAD-BUILD VERIFICATION

by

S. Kamboj, C. Yu, B.M. Biwer, and T. Klett

ABSTRACT

The results generated by the RESRAD-BUILD code (version 3.0) were verified with hand or spreadsheet calculations using equations given in the RESRAD-BUILD manual for different pathways. For verification purposes, different radionuclides — H-3, C-14, Na-22, Al-26, Cl-36, Mn-54, Co-60, Au-195, Ra-226, Ra-228, Th-228, and U-238 — were chosen to test all pathways and models. Tritium, Ra-226, and Th-228 were chosen because of the special tritium and radon models in the RESRAD-BUILD code. Other radionuclides were selected to represent a spectrum of radiation types and energies. Verification of the RESRAD-BUILD code was conducted with an initial check of all the input parameters for correctness against their original source documents. Verification of the calculations was performed external to the RESRAD-BUILD code with Microsoft® Excel to verify all the major portions of the code. In some cases, RESRAD-BUILD results were compared with those of external codes, such as MCNP (Monte Carlo N-particle) and RESRAD. The verification was conducted on a step-by-step basis and used different test cases as templates. The following types of calculations were investigated: (1) source injection rate, (2) air concentration in the room, (3) air particulate deposition, (4) radon pathway model, (5) tritium model for volume source, (6) external exposure model, (7) different pathway doses, and (8) time dependence of dose. Some minor errors were identified in version 3.0; these errors have been corrected in later versions of the code. Some possible improvements in the code were also identified.

1 INTRODUCTION

This study was conducted to verify the results generated by the RESRAD-BUILD code with hand or spreadsheet calculations performed with equations given in the RESRAD-BUILD manual (Yu et. al. 1994).

The RESRAD-BUILD computer code is a pathway analysis model designed to evaluate the potential radiological dose to an individual who works or lives in a building contaminated with radioactive material. The models in RESRAD-BUILD can be used to assess long-term chronic exposure situations, but generally they cannot be used for transient or accident situations. The code can model up to three compartments in a building. The transport of radioactive material inside the building from one compartment to another is calculated with an indoor air quality

model. The code considers the releases into the indoor air by diffusion (radon gas), mechanical removal (decontamination activities), or erosion (removable surface contamination). These three release mechanisms were tested, and the results are presented in this report. Currently, the RESRAD-BUILD database contains 67 radionuclides. For verification purposes, different radionuclides — H-3, C-14, Na-22, Al-26, Cl-36, Mn-54, Co-60, Au-195, Ra-226, Ra-228, Th-228, and U-238 — were chosen to test all pathways and models. Tritium, Ra-226, and Th-228 were chosen because of the special tritium and radon models in the RESRAD-BUILD code. Other radionuclides were selected to represent a spectrum of radiation types and energies.

The RESRAD-BUILD code considers seven exposure pathways: (1) external exposure directly from the source (i.e., the source geometry could be contaminated floors, walls, ceilings, or any other object); (2) external exposure to materials deposited on the floor; (3) external exposure due to air submersion; (4) inhalation of airborne radioactive particulates; (5) inhalation of aerosol indoor radon progeny; (6) inadvertent ingestion of radioactive material directly from the sources; and (7) inadvertent ingestion of materials deposited on the surfaces of the building rooms or compartments. The verification of the RESRAD-BUILD code was performed for individual pathway dose computations. A single run of the RESRAD-BUILD code can model a building with up to 3 rooms or compartments, 10 distinct source locations, 4 source geometries (volume, area or surface, line, and point), 10 receptor locations, 8 shielding materials, and 10 radionuclides in a source.

Verification of the RESRAD-BUILD code (version 3.0) was conducted with an initial check of all the input parameters for correctness against their original source documents (see Section 2). Verification of the calculations was performed external to the RESRAD-BUILD code with Microsoft® Excel (version 7) to verify all the major portions of the code. The verification was conducted on a step-by-step basis and used different test cases as templates, since all possible options could not be considered in a single analysis. The following types of calculations were investigated:

- Source injection rate,
- Air concentration in the room,
- Air particulate deposition,
- Radon pathway model,
- Tritium model for volume source,
- External exposure model,

- Different pathway doses, and
- Time dependence of dose.

The total receptor dose from all pathways, except direct external exposure, depends on the radionuclide air concentration in the room. The radionuclide air concentration, in turn, depends on the source injection rate. Therefore, the source injection rate calculations were verified first (see Section 3). In turn, the air concentration in a one-room and two-room model was verified (see Section 4). The air deposition depends on the air concentration in the room; therefore, air deposition was verified next (see Section 4). RESRAD-BUILD has special radon and tritium models; verification of these models is discussed in Sections 5 and 6, respectively. The external exposure models in RESRAD-BUILD were independently benchmarked with the Monte Carlo N-Particle (MCNP) transport code (Briesmeister 1993) (see Section 7). Verification of the individual pathways in RESRAD-BUILD is discussed in Section 8. Finally, the total dose calculated by RESRAD-BUILD for a single receptor was compared with that calculated by the Excel spreadsheet. The time-independent part of the code was tested first (instantaneous dose calculations at time zero without averaging over one year or exposure duration). Verification of the time-dependent part of the code is presented in Section 9. Section 10 provides conclusions, and Section 11 discusses the limitations of this verification and gives suggestions for future improvement of the code. The output files from the RESRAD-BUILD (version 3.0) verification runs are provided in the Appendix. (This appendix is provided in the companion CD-ROM to this document.)

2 PARAMETER VERIFICATION

The following parameters used in the RESRAD-BUILD code (version 3.0) were first checked for correctness against their original source documents: inhalation, ingestion, air submersion, and external dose conversion factors (DCFs); external exposure model parameters; and radionuclide half-lives and other decay data. The files checked were nucdcf.dat, GP_ABS.LIB, and coeff_bd.lib.

The nucdcf.dat file contains DCFs for ingestion, inhalation, external-surface, external-volume, and immersion pathways. It also includes half-lives, total number of gammas emitted, and the number of branching radionuclides. The values of external-surface DCFs are not used in any calculations and may be removed from the nucdcf.dat file. The values of half-lives in the nucdcf.dat file have only three significant digits; the significant digits should be increased to match the actual half-lives of radionuclides. Table 2.1 lists the errors noted in the nucdcf.dat file.

The GP_ABS.LIB file contains the geometric progression (G-P) buildup factor coefficients for different materials available in the RESRAD-BUILD code. For some materials, energy absorption buildup factor coefficients were used rather than exposure buildup factor coefficients. It is recommended that G-P exposure buildup factor coefficients be used for all materials.

The coeff_bd.lib file contains parameters required to compute the external pathway dose for surface (area) and volume sources. The parameters are the external DCFs for volume sources, fitted coefficients of the external exposure model, collapsed gamma energies,¹ and respective gamma fractions of radionuclides (Kamboj et al. 1998). The GP_ABS.LIB file has only two significant digits for some of the external exposure model parameters. The significant digits should be increased to three to obtain a better estimation of the external pathway dose for a surface and volume source.

TABLE 2.1 Errors Noted in nucdcf.dat File

Parameter	Nuclide	Present Value	Correct Value
Half-life (yr)	Ac-227	2.17E+01	2.18E+01
Half-life (yr)	Zn-65	6.67E-01	6.68E-01
Inhalation DCF (mrem/pCi)	Ce-144	2.16E-04	3.74E-04
Inhalation DCF (mrem/pCi)	Pm-147	2.58E-05	3.92E-05

¹ To conserve computational time without sacrificing accuracy, the photon energies and yields from International Commission on Radiological Protection (ICRP) Publication 38 (ICRP 1983) were condensed into a smaller number of energies and yields for each radionuclide. The spectra-condensing algorithms, which conserve energy, repeatedly combine the photons that are closest in their energies (using their ratio).

For verification of the calculations, Excel spreadsheets were prepared that calculated the different pathway doses according to the source receptor configuration. Three spreadsheets were used for all verification runs. The first spreadsheet contains all the RESRAD-BUILD default parameters, the second has lower values of the input parameters, and the third has all the upper values for the input parameters. The lower and upper values of the parameters are from Yu et al. (2000). The verification was performed for three data sets to cover wide variations in input values. Table 2.2 gives the input parameter values that were used for comparison, the parameter names used in the dose calculations, and the units for each parameter. In some cases, the units vary. For example, the radionuclide concentration for a volume source is input in pCi/g, and in the calculations, source concentration used may be in pCi/kg; deposition velocity is input in m/s, and in the calculations, it is used in units of m/h.

For RESRAD-BUILD many input test case files (in all 17) were generated. The first case included four Na-22 sources, four Al-26 sources (one each of volume, surface, line, and point sources), and one H-3 volume source, all with RESRAD-BUILD default values. The second and third cases were with the same sources with lower and upper parameter bound values. RESRAD-BUILD allows only 10 sources as input in a single run; therefore, 3 separate cases with default, lower, and upper bound values were generated with Ra-226 and Th-228 point and volume sources. To verify the two-room air quality model, three more case files with default, lower bound, and upper bound parameter values, respectively, were used. To verify the external exposure model for point, line, area, and volume sources, four separate case files were used. Table 2.3 lists all the case files used in the verification of different calculations. The RESRAD-BUILD output files generated and used are also listed. All RESRAD-BUILD input and output files are provided in the Appendix.

TABLE 2.2 Parameters and Parameter Values Used in RESRAD-BUILD Verification

Parameter	Parameter Name	Parameter Value		
		Default	Lower ^a	Upper ^a
Exposure duration, d	ED	365	365	365
Indoor fraction	F _{IN}	0.5	0.205	1.0
Evaluation time, yr	t	0	0	0
Deposition velocity, m/s	U _d	0.01	0	0.01
Resuspension rate, 1/s	λ _R	5.0E-07	1.2E-10	4E-04
Room height (room 1), m	H ₁	2.5	1.67	3.75
Room height (room 2), m	H ₂	2.5	1.67	3.75
Room area (room 1), m ²	A ₁	36	3.6	360
Room area (room 2), m ²	A ₂	36	3.6	360
Air exchange rate for building, 1/h	λ ^a _b	0.8	0.1796	1.5185
Air flow from outside to compartment 1	Q ₀₁ (flow01)	84	1.16	4,065
Air flow from outside to compartment 2	Q ₀₂ (flow02)	60	1	35
Air flow from compartment 1 to compartment 2	Q ₁₂ (flow12)	30	4	180.2
Air flow from compartment 2 to compartment 1	Q ₂₁ (flow21)	30	4.5	175.2
Number of receptors	NA ^b	1	1	1
Receptor inhalation rate, m ³ /d	IR	18	12	45.6
Receptor location, m	NA	1,1,1	1,1,1	5,5,1
Receptor indirect ingestion rate, m ² /h	SER	0.0001	0.0001	0.011
Receptor time in room 1	FI ₁	1	1	1
Receptor time in room 2	FI ₂	1	1	1
Number of sources	NA	1	1	1
Source location, m	NA	0,0,0	0,0,0	0,0,0
Source length or area (m, m ²)	L _s , A _s	36	3.6	360
Air release fraction	f	0.1	0.01	1
Direct ingestion rate, g/h (volume source)	ER	0	0	0.0025
Direct ingestion rate, 1/h (area, line, and point)	ER _i	0	0	0.00005
Removable fraction	f _R	0.5	0.01	0.5
Time for source removal or source lifetime, d	T _R	365	365	36,500
Radionuclide concentration, pCi/g (volume); pCi/m ² (surface); pCi/m (line); pCi (point)	C ⁿ _S , Q ⁿ _S	1	1	1
Source material	NA	Concrete	Concrete	Concrete
Number of regions in volume source	NA	1	1	1
Contaminated region – volume source	NA	1	1	1
Source thickness, cm	t _s	15	5	30
Source density, g/cm ³	ρ _{bs}	2.4	2	4
Source erosion rate, cm/d	E	2.4E-08	2.4E-10	2.4E-06
Shielding material	NA	NA	NA	Concrete
Shielding thickness, cm	t _c	0	0	15
Shielding density, g/cm ³	ρ _c	NA	NA	2.4
Dry zone thickness, cm	h	0	0	5
Wet + dry zone thickness, cm	h _p	10	5	30
Moisture content in the wet zone	W	0.03	0.02	0.06
Water fraction available for evaporation	f _{rel}	1	0.1	1
Humidity, g/m ³	C _{g,amb}	8	3	16.5
Source porosity	n	0.1	0.05	0.2
Radon release fraction	F _{Rn}	0.1	0.02	0.5

TABLE 2.2 (Cont.)

Parameter	Parameter Name	Parameter Value		
		Default	Lower ^a	Upper ^a
Rn-222 emanation coefficient	ϵ	0.2	0.04	1.0
Rn-220 emanation coefficient	ϵ	0.2	0.04	1.0
Radon effective diffusion coefficient, m ² /s	D_e	2.0E-05	2.0E-06	2.0E-04

^a The lower and upper parameter values are from Yu et al. (2000).

^b NA = not applicable.

TABLE 2.3 Cases Used in RESRAD-BUILD Verification

Calculations Verified	Input	Output	Parameter	Air Quality Model	Source	Radionuclide
Source injection rate	Case 1	diag.out	Default	One-room	Point, line, surface, and volume	Na-22
	Case 2	diag.out	Lower bound			
	Case 3	diag.out	Upper bound			
Air concentration	Case 1	diag.out	Default	One-room	Point, line, surface, and volume	Na-22 and Al-26
	Case 2	diag.out	Lower bound			
	Case 3	diag.out	Upper bound	Two-room		
	Case 4	diag.out	Default			
	Case 5	diag.out	Lower bound			
	Case 6	diag.out	Upper bound			
Radon pathway (injection rate and progeny air concentration)	Case 7	diag.out	Default	One-room	Point and volume	Ra-226 and Th-228
	Case 8	diag.out	Lower bound			
	Case 9	diag.out	Upper bound			
External exposure model	Case 10a	resradb.rpt	Default	One-room	Volume, area, line, and point	Au-195, Mn-54, Co-60
	Case 10	resradb.rpt	Indoor fraction = 1, receptor = 0.01, 0.1, 0.15, 1, and 10 m; area = 3.2 m ² ; thickness = 0.01, 0.1, and 0.5 m; length = 0.01, 0.1 1, and 10 m	One-room	Point	Au-195, Mn-54, Co-60
Time integration	Case 11	resradb.rpt	"	One-room	Area Volume Line	Ra-228
	Case 12	resradb.rpt	"			
	Case 13	resradb.rpt	"			
	Case 14 and case 15	resradb.rpt	T = time-int (5) T = 0.2, 0.4, 0.6, 0.8, and 1.0 yr	One-room	Volume	

TABLE 2.3 (Cont.)

Calculations Verified	Input	Output	Parameter	Air Quality Model	Source	Radionuclide
Source erosion rate	Case 16	resradb.rpt	Erosion rate = 4.8E-3 cm/d; $T = 0, 1, 2, 3, 4, 5, 6, 7,$ and 8 yr; area = 100,000 m ²	One-room	Volume	Ra-226
Radioactive decay and in-growth	Case 17 testbd.rad	resradb.rpt concent.rpt (RESRAD)	$t = 0, 1, 3, 10, 30, 100, 300,$ and 1,000 yr	One-room	Volume	U-238, Ra-228
Pathway Doses: ^a submersion, ^b inadvertent ingestion directly from the source, ^c inadvertent ingestion of deposited materials, ^d inhalation, ^b radon, ^e direct external exposure, ^f external exposure to deposited material, ^g tritium volume source ^h	Case 1 Case 2 Case 3	resradb.rpt	Default Lower bound Upper bound	One-room	Point, line, surface, and volume	Ra-226 and Th-228 for radon inhalation; H-3 for tritium volume source; and Na-22 and Al-26 for others.

^a For pathway verification cases 1, 2, and 3, input files were used except for the changes marked in individual pathways.

^b No change.

^c Receptor indirect ingestion set to zero (Case 1-DI, Case 2-DI, and Case 3-DI).

^d Receptor direct ingestion set to zero (Case 1, Case 2, and Case 3-II).

^e Radionuclides selected were Ra-226 and Th-228 rather than Na-22 and Al-26, and the source types were point and volume only (Case 7, Case 8, and Case 9).

^f Sources were assumed to have a large area to avoid calculation of an area factor, and the receptor was at 1 m from the center of the source to avoid calculation of an off-set factor (Case 1E, Case 2E, and Case 3E).

^g A large floor area of the room was assumed (Case 1ED, Case 2ED, and Case 3ED).

^h The radionuclide selected was H-3, and the volume source was considered.

3 SOURCE INJECTION RATE

For a volume source, the release rate of a principal radionuclide n into compartment i is calculated by (Yu et al. 1994, Equation D.1):

$$I_{Si}^n = \frac{f E A_s \rho_{bs} C_s^n}{8,760}, \quad (3.1)$$

where

I_{Si}^n = injection rate of radionuclide n into the indoor air of compartment i (pCi/h),

f = fraction of mechanically removed or eroded material that becomes indoor dust (air release fraction),

E = source removal or erosion rate (m/yr),

A_s = effective surface area of the source (m²),

ρ_{bs} = bulk density of the source material (kg/m³),

C_s^n = radionuclide concentration in the source material (pCi/kg), and

8,760 = time conversion factor (number of hours per year) (h/yr).

For surface, line, and point sources, the release rate of a principal radionuclide n into compartment i is calculated by (Yu et al. 1994, Equation D.2):

$$I_{Si}^n = \frac{f_R f Q_s^n}{24T_R}, \quad (3.2)$$

where

f_R = removable fraction of the source material,

f = fraction of removed material that becomes indoor dust (air release fraction),

Q_s^n = total radionuclide activity in the source (pCi),

T_R = time to remove material from the source (d), and

24 = time conversion factor (number of hours per day) (h/d).

Table 3.1 presents a comparison of the calculated injection rate for volume, area, line, and point sources. RESRAD-BUILD results from test cases 1, 2, and 3 are compared with the spreadsheet calculations. Equation 3.1 (Equation D.1 in Appendix D of the RESRAD-BUILD manual) was used in the spreadsheet to calculate the injection rate for a volume source, and Equation 3.2 (Equation D.2 in Appendix D of the RESRAD-BUILD manual) was used for area, line, and point sources. Figure 3.1 shows the spreadsheet calculations for the default parameter set. Table 3.1 gives the RESRAD-BUILD and spreadsheet calculated values of the source injection rate for the three sets of parameters for Na-22. The Appendix has the code generated diag.out file for test cases 1, 2, and 3, which includes the source injection rate for all four source types (point, line, surface, and volume). The injection rate depends on the source concentration at time zero. The source injection models (Equations 3.1 and 3.2) are used for all radionuclides except for the H-3 volume source and radon progeny radionuclides. The injection rates for the tritium volume source and radon progeny are discussed in Sections 5 and 6, respectively. The RESRAD-BUILD detailed output file (diag.out) reported source injection rate results in pCi/s and only to two significant digits; therefore, for comparison, the spreadsheet calculated source injection rate in pCi/h (according to the RESRAD-BUILD manual) was converted to pCi/s. Excellent agreement was obtained between the RESRAD-BUILD generated results and the spreadsheet calculations. However, the significant digits in the diag.out file should be increased, or the units of the injection rate changed to pCi/h.

TABLE 3.1 Comparison of RESRAD-BUILD and Spreadsheet Values for Source Injection Rate (pCi/h)

Source Type	Default Value		Lower Bound Value		Upper Bound Value	
	RESRAD-BUILD ^a (pCi/s)	Spreadsheet (pCi/h)	RESRAD-BUILD ^b (pCi/s)	Spreadsheet (pCi/s)	RESRAD-BUILD ^c (pCi/s)	Spreadsheet (pCi/h)
Volume	2.4E-08	2.4E-08	2.0E-12	2.0E-12	4.0E-04	4.0E-04
Area	5.7E-08	5.7E-08	1.1E-11	1.1E-11	5.7E-08	5.7E-08
Line	5.7E-08	5.7E-08	1.1E-11	1.1E-11	5.7E-08	5.7E-08
Point	1.6E-09	1.6E-09	3.2E-12	3.2E-12	1.6E-10	1.6E-10

^a Source injection rate from test case 1.

^b Source injection rate from test case 2.

^c Source injection rate from test case 3.




FIGURE 3.1 Source Injection Rate Calculations for Volume, Surface, Line, and Point Sources

4 AIR CONCENTRATION AND PARTICULATE DEPOSITION

From the one-room air quality model, the air concentration of principal radionuclide n (derived from Equation A.28 in the RESRAD-BUILD manual) can be given as:

$$C_1^n = \frac{I_{S1}^n}{(\lambda_m + \lambda_{d1} - \frac{\lambda_R \lambda_{d1}}{\lambda_m + \lambda_R})V_1 + Q_{01}}, \quad (4.1)$$

where

C_1^n = air concentration of radionuclide n in compartment 1,

λ_m = radioactive decay constant of radionuclide n ,

λ_{d1} = deposition rate in compartment 1,

λ_R = resuspension rate,

V_1 = volume of compartment 1, and

Q_{01} = flow of air from compartment 1 to the outside.

The deposition rate can be given as:

$$\lambda_{d1} = \frac{u_d A_1}{V_1}, \quad (4.2)$$

where

u_d = deposition velocity, and

A_1 = area of compartment (room) 1.

For the one-room model, the flow of air from compartment 1 to the outside can be calculated as:

$$Q_{01} = \lambda_b^a V_1, \quad (4.3)$$

where λ_b^a is the building air exchange rate.

Figure 4.1 shows the calculated air concentration using the default parameter set for all seven radionuclides for the volume, area, line, and point sources. Equations 4.1 through 4.3 were used in these calculations. Table 4.1 provides the RESRAD-BUILD (test cases 1, 2, and 3) and spreadsheet calculated values of the air concentration for the three sets of parameters (default, lower bound, and upper bound) for the one-room model. The diag.out files for cases 1, 2, and 3 in the Appendix include the RESRAD-BUILD code generated air concentrations for four source types for the one-room air quality model. As shown in Table 4.1 for the Na-22 and Al-26 radionuclides at time zero, excellent agreement was obtained between the RESRAD-BUILD and spreadsheet calculations.

For the two-room air quality model, the air concentration of principal radionuclide n (derived from Equation A.28 in the RESRAD-BUILD manual) can be given as:

$$C_1^n = \frac{D_1 I_{S2}^n + D_2 I_{S1}^n}{C_1 D_2 - D_1 C_2}, \quad (4.4)$$

and

$$C_2^n = \frac{C_1 I_{S2}^n + C_2 I_{S1}^n}{C_1 D_2 - D_1 C_2}. \quad (4.5)$$

The injection rates in compartments 1 and 2 were calculated using Equations 3.1 and 3.2 for volume, area, line, and point sources. The C_1 , C_2 , D_1 , and D_2 parameters were given as:

$$C_1 = (\lambda_m + \lambda_{d1} - \frac{\lambda_R \lambda_{d1}}{\lambda_m + \lambda_R}) V_1 + Q_{01} + Q_{21}, \quad (4.6)$$

$$C_2 = Q_{12}, \quad (4.7)$$

$$D_1 = Q_{21}, \text{ and} \quad (4.8)$$

$$D_2 = (\lambda_m + \lambda_{d2} - \frac{\lambda_R \lambda_{d2}}{\lambda_m + \lambda_R}) V_2 + Q_{02} + Q_{12}. \quad (4.9)$$




FIGURE 4.1 Calculated Air Concentrations for Volume, Surface, Line, and Point Sources for the One-Room Air Quality Model

TABLE 4.1 RESRAD-BUILD and Spreadsheet Air Concentration (pCi/m³) Values for the One-Room Air Quality Model

Source Type	Default		Lower		Upper	
	RESRAD-BUILD ^a	Spreadsheet	RESRAD-BUILD ^b	Spreadsheet	RESRAD-BUILD ^c	Spreadsheet
Na-22						
Volume	9.2E-07	9.24E-07	6.7E-09	6.65E-09	7.1E-04	7.11E-04
Area	2.2E-06	2.20E-06	3.8E-08	3.80E-08	1.0E-07	1.01E-07
Line	2.2E-06	2.20E-06	3.8E-08	3.80E-08	1.0E-07	1.01E-07
Point	6.1E-08	6.10E-08	1.1E-08	1.05E-08	2.8E-10	2.82E-10
Al-26						
Volume	1.2E-06	1.20E-06	6.7E-09	6.65E-09	7.1E-04	7.11E-04
Area	2.9E-06	2.85E-06	3.8E-08	3.80E-08	1.0E-07	1.01E-07
Line	2.9E-06	2.85E-06	3.8E-08	3.80E-08	1.0E-07	1.01E-07
Point	7.9E-08	7.93E-08	1.1E-08	1.05E-08	2.8E-10	2.82E-10

^a Air concentrations from test case 1.

^b Air concentrations from test case 2.

^c Air concentrations from test case 3.

The deposition rates for compartments 1 and 2 were calculated using Equation 4.2. The air flow rates, Q_{21} , quantity of air going from compartment 2 to compartment 1; Q_{12} , quantity of air going from compartment 1 to 2; Q_{01} , inflow to compartment 1; and Q_{02} , inflow to compartment 2 are required to calculate the air concentration. If the building parameters, such as building and room exchange rates, net flow between compartments 1 and 2, and inflow to compartment 2 are known, the air flow rates can be calculated. Unknown parameters can be calculated in many ways. For example, if the exchange rate for compartments 1 and 2 (λ_1^a and λ_2^a), net flow between compartments 1 and 2 (N_{12}), and inflow to compartment 2 are known, then the other parameters can be calculated as:

$$Q_{12} = \lambda_2^a - Q_{02} , \quad (4.10)$$

$$Q_{21} = Q_{12} - N_{12} , \text{ and} \quad (4.11)$$

$$Q_{01} = \lambda_1^a V_1 - Q_{21} . \quad (4.12)$$

Figures 4.2 and 4.3 show the calculated air concentration using the default parameter set for all seven radionuclides for the volume, point, line, and area sources, respectively. Figure 4.4 provides the in-between calculation results. Equations 4.4 through 4.12 were used in these calculations. Table 4.2 gives the RESRAD-BUILD (test cases 4, 5, and 6) and spreadsheet




FIGURE 4.2 Calculated Air Concentrations for the Volume Source for the Two-Room Air Quality Model




FIGURE 4.3 Calculated Air Concentrations for Point, Line, and Surface Sources for the Two-Room Air Quality Model




FIGURE 4.4 In-between Calculations for the Two-Room Air Quality Model

TABLE 4.2 RESRAD-BUILD and Spreadsheet Air Concentration (pCi/m³) Values for the Two-Room Air Quality Model

Source Type	Default		Lower		Upper	
	RESRAD-BUILD ^a	Spreadsheet	RESRAD-BUILD ^b	Spreadsheet	RESRAD-BUILD ^c	Spreadsheet
Na-22 (Air concentration in room 1 with source in room 1)						
Volume	6.8E-07	6.78E-07	3.5E-09	3.49E-09	3.5E-04	3.52E-04
Area	1.6E-06	1.61E-06	2.0E-08	1.99E-08	5.0E-08	5.02E-08
Line	1.6E-06	1.61E-06	2.0E-08	1.99E-08	5.0E-08	5.02E-08
Point	4.5E-08	4.48E-08	5.5E-09	5.54E-09	1.4E-10	1.39E-10
Na-22 (Air concentration in room 2 with source in room 1)						
Volume	1.8E-07	1.82E-07	2.8E-09	2.80E-09	2.9E-04	2.94E-04
Area	4.3E-07	4.34E-07	1.6E-08	1.60E-08	4.2E-08	4.20E-08
Line	4.3E-07	4.34E-07	1.6E-08	1.60E-08	4.2E-08	4.20E-08
Point	1.2E-08	1.20E-08	4.4E-09	4.43E-09	1.2E-10	1.17E-10
Al-26 (Air concentration in room 1 with source in room 1)						
Volume	8.3E-07	8.31E-07	3.5E-09	3.49E-09	3.5E-04	3.52E-04
Area	2.0E-06	1.98E-06	2.0E-08	1.99E-08	5.0E-08	5.02E-08
Line	2.0E-06	1.98E-06	2.0E-08	1.99E-08	5.0E-08	5.02E-08
Point	5.5E-08	5.49E-08	5.5E-09	5.54E-09	1.4E-10	1.39E-10
Al-26 (Air concentration in room 2 with source in room 1)						
Volume	2.8E-07	2.77E-07	2.8E-09	2.80E-09	2.9E-04	2.95E-04
Area	6.6E-07	6.59E-07	1.6E-08	1.60E-08	4.2E-08	4.20E-08
Line	6.6E-07	6.59E-07	1.6E-08	1.60E-08	4.2E-08	4.20E-08
Point	1.8E-08	1.83E-08	4.4E-09	4.43E-09	1.2E-10	1.17E-10

^a Air concentrations from test case 4.

^b Air concentrations from test case 5.

^c Air concentrations from test case 6.

calculated values of the air concentration for the three sets of parameters (default, lower bound, and upper bound) for the two-room air quality model. The diag.out files for cases 4, 5, and 6 in the Appendix include the air concentrations for four source types generated by the RESRAD-BUILD code for the two-room air quality model. Again, as shown in Table 4.2, excellent agreement was obtained between the code output and the spreadsheet calculations for the Na-22 and Al-26 radionuclides at time zero.

The air particulate deposition model in RESRAD-BUILD evaluates the surface contamination, C_{di}^n , due to deposition of the principal radionuclide of order n in the decay series, in each compartment, i , of the building, as a function of the respective airborne concentration in

that compartment. Assuming a steady-state condition, the surface contamination can be given as (Equation B.3 in the RESRAD-BUILD manual):

$$C_{di}^n = \left(\frac{u_d}{\lambda_m + \lambda_R} \right) C_i^n . \quad (4.13)$$

Equation 4.13 was used to calculate the air particulate deposition in each compartment as a function of the respective air concentration. Figure 4.5 shows the calculated air particulate deposition for the default parameter set for the one- and two-room air quality models. The surface particle contamination due to deposition was used in calculating the inadvertent ingestion pathway dose directly from the deposited materials and the external exposure pathway dose (Sections 8.3 and 8.7, respectively).

CDIN: surface concentration of radionuclide n , deposited onto horizontal surfaces of compartment 1 for volume sources (pCi/m²):

$$CD1N \text{ (pCi/m}^2\text{)} = (ud/\text{lambdaRN} + \text{lambdaR}) * C1N \quad \text{(Eq. 4.13)}$$

Resultant Surface Concentration (pCi/m²)

Volume

H-3	2.21E+05
C-14	2.40E-02
Na-22	1.82E-02
Al-26	2.40E-02
Cl-36	2.40E-02
Ra-226	2.40E-02
Th-228	1.67E-02

CDIN: surface concentration of radionuclide n , deposited onto horizontal surfaces of compartment 1 for point, line, and surface sources (pCi/m²):

$$CD1N \text{ (pCi/m}^2\text{)} = (ud/\text{lambdaRN} + \text{lambdaR}) * C1N \quad \text{(Eq. 4.13)}$$

Resultant Surface Concentration (pCi/m²)

Point

	Line	Area
H-3	1.48E-03	5.35E-02
C-14	1.59E-03	5.71E-02
Na-22	1.20E-03	4.32E-02
Al-26	1.59E-03	5.71E-02
Cl-36	1.59E-03	5.71E-02
Ra-226	1.58E-03	5.70E-02
Th-228	1.10E-03	3.97E-02

Surface concentration of radionuclide n , deposited onto horizontal surfaces of compartment 1

$$CDIN(H-3) \text{ (pCi/m}^2\text{)} = \left(\frac{36 \text{ ud (m/h)}}{6.42E-06 \text{ lambdaRN (1/h)}} + \frac{1.80E-03 \text{ lambdaR (1/h)}}{1.11E+01 \text{ CIN (pCi/m}^3\text{)}} \right) *$$

FIGURE 4.5 Calculated Surface Concentration from Deposition

5 RADON PATHWAY MODEL

The radon pathway dose estimation involved the following four calculations:

1. The indoor air concentration of radon and its decay products;
2. The working level (WL) based on the values of air concentrations;
3. The exposure in working level month (WLM) to the radon decay products, based on the WL and exposure duration; and
4. The effective dose equivalent based on the WL and the related DCFs.

The indoor radon concentration in the indoor air of compartment i was calculated by using the air quality model. To apply the air quality model, the radon injection rate was evaluated. The airborne concentration of radon progeny was then calculated sequentially by applying the mass balance equations.

The WL_i value in compartment i for an indoor atmosphere containing a mixture of radon (Rn-222) progeny was evaluated as (Yu et al. 1994, Equation C.32):

$$WL_i^{Rn-222} = (1.03 \times 10^{-6}) C_i^2 + (5.07 \times 10^{-6}) C_i^3 + (3.73 \times 10^{-6}) C_i^4, \quad (5.1)$$

where C_i^2 , C_i^3 , and C_i^4 are the concentrations of Po-218, Pb-214, and Bi-214, respectively, in the indoor air of compartment i (pCi/m³). Similarly, for thoron (Rn-220), the WL_i value was evaluated as (Yu et al. 1994, Equation C.33):

$$WL_i^{Rn-220} = (9.48 \times 10^{-10}) C_i'^2 + (1.23 \times 10^{-4}) C_i'^3 + (1.17 \times 10^{-5}) C_i'^4, \quad (5.2)$$

where $C_i'^2$, $C_i'^3$, and $C_i'^4$ are the concentrations of Po-216, Pb-212, and Bi-212, respectively, in the indoor air of compartment i (pCi/m³).

The radon progeny concentration is measured in units of WLMs, which for each compartment i can be calculated as (Yu et al., 1994, Equation C.34):

$$WLM_i = \left(\frac{8,760}{170}\right) F_{in} F_i WL_i, \quad (5.3)$$

where

8,760 = number of hours per year (h/yr), and

170 = number of working hours per month (h).

The effective dose equivalent due to the exposure to radon decay products in the indoor air of each compartment i can be evaluated as (Yu et al. 1994, Equation C.37):

$$D_i = K WLM_i DCF, \quad (5.4)$$

where

D_i = effective dose equivalent due to exposure to radon decay products (from either Rn-222 or Rn-220) in compartment i (mrem/yr);

DCF = dose conversion factor for the inhalation of radon decay products (mrem/WLM); and

K = multiplication factor to account for the extrapolation of doses from uranium mines to homes.

For the Rn-222 decay products, the values of the DCF and the K factor are equal to 1,000 (mrem/WLM) and 0.76 (dimensionless), respectively. Similarly, for the Rn-220 decay products, the values of the DCF and the K factor are equal to 350 (mrem/WLM) and 0.42 (dimensionless), respectively. The values of the DCF and the K factor for the Rn-222 and Rn-220 decay products are consistent with those used in RESRAD.

5.1 RADON INJECTION RATE

The rate of radon injection into the indoor air depends on the concentration of the radon parent within the source and on the geometric and physical properties of the source. Therefore, the injection rate (I_{Si}^{Rn}) is defined for each type of source: surface, line, point, and volume. For surface, line, and point sources, I_{Si}^{Rn} (pCi/s) is calculated as (Yu et al. 1994, Equation C.1):

$$I_{Si}^{Rn} = F^{Rn} \lambda A_{total}^p, \quad (5.5)$$

where

F^{Rn} = fraction of radon generated within the source that escapes from the source and is injected into the air (dimensionless),

λ = radon decay constant (s^{-1}), and

A^P_{total} = total amount of the radon parent radionuclide present within the source (pCi).

For a volume source, the radon injection rate, I_{Si}^{Rn} , is evaluated differently, according to the following (Yu et al. 1994, Equation C.2):

$$I_{Si}^{Rn} = A_s J, \quad (5.6)$$

where

A_s = surface area of the face of the volume source that is exposed to the indoor air of compartment i (m^2), and

J = flux density of radon activity (or radon flux, for short) through the exposed face of the volume source ($pCi \times m^{-2} \times s^{-1}$).

The variables F^{Rn} and A^P_{total} are given as input parameters to the model. Therefore, the calculation of I_{Si}^{Rn} for surface, line, and point sources is a straightforward procedure, based directly on Equation 5.5. For volume sources, the radon flux is not given as an input parameter and must be evaluated specifically for each case. Appendix C of the RESRAD-BUILD manual describes how the radon flux is calculated. Figure 5.1 shows the radon flux calculations for a volume source using all default parameters. The radon injection rates are printed in a detailed report titled diag.out after the calculations are completed. The diag.out files for cases 7, 8, and 9 in the Appendix include the radon injection rates generated by the RESRAD-BUILD code for point and volume sources of Ra-226 and Th-228 contamination. Table 5.1 presents a comparison of the spreadsheet calculated values of Ra-226, Th-228, Rn-222, and Rn-220 injection rates for point and volume sources with the RESRAD-BUILD code generated values. Since the method used for point, line, and area sources is the same, only point source values were compared. Figure 5.2 shows the spreadsheet calculations for point and volume sources. The values for the Ra-226 and Th-228 injection rates for a volume and point source are from Figure 3.1. The unit conversion from hour to second was applied. For the point source, there was no difference in the RESRAD-BUILD and spreadsheet calculations. However, the volume source injection rates for Rn-222 and Rn-220 were different in two cases. The difference is due to the density used in the calculations. For the spreadsheet calculations, it was assumed that the particle density is input;




FIGURE 5.1 Radon Flux Calculations for a Volume Source

Ra-226	- 2.21E+06								
Th-228	- 4.22E+06								
J(pCi/m ² -h): radon flux									
J(x = 0) = -n * De * r1 * (k11 - k12) (Yu et al., 1994, Eq. C.16)									
- 2.45E+02	=	1.00E-01	*	7.20E-02	*	(2.11E+06	-	2.21E+06
J(x = 0)/(Ra - 226)		N		De		k11	k12)
Ra-226	- 2.45E + 02								
Th-228	- 7.41E + 05								
J(x = 1) = -n * De * r1 * (k11 * exp(r1 * L) - k12 * exp(-r1 * L)) (Yu et al., 1994, Eq. C.17)									
- 2.45E + 02	=	1.00E-01	*	7.20E - 02	*	(2.11E + 06	*	exp(
J(x = 1)/(Ra -26)		N		De		r1	3.24E - 01	*	r1
							L	*	2.21E+06
)	*	- 3.24E-01
							L	*	-r1
)	*	2.21E+06
									k12
Ra-226	- 2.45E + 02								
Th-228	- 7.41E + 05								
IS1RN(pCi/h): radon injection rate									
IS1RN(x = 0) = As * J(x = 0) (Yu et al., 1994, Eq. C.2)									
-8.81E + 03	=	36	*	-2.45E + 02					
IS1RN(x = 0)/(Ra-226)		As		J(x = 0)					
Ra-226	- 8.81E+03								
Th-228	- 2.67E+07								
IS1RN(x = 1) = As * J(x = 1) (Yu et al., 1994 Eq. C.2)									
8.81E + 03	=	36	*	2.45E + 02					
IS1RN(x = 1)/(Ra-226)		As		J(x = 1)					
Ra-226	8.81E + 03								
Th-228	2.67E + 07								

FIGURE 5.1 (Cont.)

TABLE 5.1 RESRAD-BUILD and Spreadsheet Injection Rates (pCi/s) for Ra-226 and Th-228 Point and Volume Sources for Three Sets of Input Parameters

	RESRAD-BUILD			Spreadsheet		
	Default ^a	Lower ^b	Upper ^c	Default	Lower	Upper
Point Source						
Ra-226	1.6E-09	3.2E-12	1.6E-10	1.6E-09	3.2E-12	1.6E-10
Rn-222	2.1E-07	4.2E-08	1.1E-06	2.10E-07	4.2E-08	1.05E-06
Th-228	1.6E-09	3.2E-12	1.6E-10	1.6E-09	3.2E-12	1.6E-10
Rn-220	1.2E-03	2.5E-04	6.2E-03	1.25E-03	2.49E-04	6.23E-03
Volume Source						
Ra-226	2.4E-08	2.0E-12	4.0E-04	2.4E-08	2.0E-12	4.0E-04
Rn-222	5.4	3.0E-02	910	5.44 ^d	3.02E-02	906
Th-228	2.4E-08	2.0E-12	4.0E-04	2.4E-08	2.0E-12	4.0E-04
Rn-220	1.6E+04	8.8E+01	3.8E+06	1.65E+04 ^e	8.75E+01	3.77E+06

^a Injection rates from test case 7.

^b Injection rates from test case 8.

^c Injection rates from test case 9.

^d If particle density is input, the injection rate = 4.89 pCi/s.

^e If particle density is input, the injection rate = 1.48E+04 pCi/s.

whereas in RESRAD-BUILD, the source bulk density was assumed. If the density is changed in the spreadsheet, the results are the same (within round-off errors) as the RESRAD-BUILD code output.

5.2 RADON PROGENY CONCENTRATION

The radon progeny concentrations are also printed in the diag.out file after the calculations are completed. The calculated values of the Ra-226 and Th-228 progeny concentrations for a point and volume source were compared with the RESRAD-BUILD values (test cases 7, 8, and 9) in Table 5.2. Since the methods used for a point, line, and area source are the same, only point source values were compared. Figure 5.3 shows the spreadsheet calculations of the radon progeny concentrations for the default parameter sets for a point source. Equations used in calculating progeny concentrations were from the RESRAD-BUILD manual (Equations C.18 – C.31).

The radon decay products may exist in the free (fr), attached (at), or plate-out (po) state. Figure 5.3 shows the air concentration of the decay products in these states (free, attached, and plate-out). The values of the rate constants and the probability of attachment used in the




FIGURE 5.2 Injection Rates for Rn-222 and Rn-220 for a Point and Volume Source

TABLE 5.2 RESRAD-BUILD and Spreadsheet Air Concentrations (pCi/m³) for Ra-226 and Th-228 and Their Progeny for Three Sets of Input Parameters

	RESRAD-BUILD			Spreadsheet		
	Default ^a	Lower ^b	Upper ^c	Default	Lower	Upper
Point Source						
Ra-226	7.9E-08	1.1E-08	2.8E-10	7.92E-08	1.05E-08	2.82E-10
Rn-222	1.0E-05	1.3E-04	1.9E-06	1.04E-05	1.34E-04	1.86E-06
Po-218	2.9E-06	7.0E-05	6.1E-07	2.92E-06	7.01E-05	6.06E-07
Pb-214	2.7E-07	5.3E-05	1.1E-07	2.65E-07	5.26E-05	1.07E-07
Bi-214	3.1E-08	4.8E-05	2.4E-08	3.12E-08	4.83E-05	2.37E-08
Th-228	5.6E-08	1.1E-08	2.8E-10	5.65E-08	1.05E-08	2.82E-10
Rn-220	1.1E-03	3.3E-03	3.6E-04	1.09E-03	3.31E-03	3.58E-04
Po-216	1.1E-03	3.3E-03	3.6E-04	1.09E-03	3.31E-03	3.58E-04
Pb-212	2.7E-06	4.4E-04	5.9E-06	2.70E-06	4.40E-04	5.95E-06
Bi-212	1.1E-07	3.5E-04	7.7E-07	1.11E-07	3.48E-04	7.66E-07
Volume Source						
Ra-226	1.2E-06	6.7E-09	7.1E-04	1.20E-06	6.65E-09	7.11E-04
Rn-222	270	97	1600	269	96.4	1600
Po-218	76	50	520	75.6	50.4	523
Pb-214	6.9	38	92	6.86	37.8	92.2
Bi-214	0.80	35	20	0.809	34.7	20.5
Th-228	8.5E-07	6.7E-09	7.1E-04	8.55E-07	6.65E-09	7.11E-04
Rn-220	1.4E+04	1.2E+03	2.2E+05	1.44E+04	1.16E+03	2.17E+05
Po-216	1.4E+04	1.2E+03	2.2E+05	1.44E+04	1.16E+03	2.17E+05
Pb-212	36	150	3.6E+03	35.7	154	3.60E+03
Bi-212	1.5	120	460	1.46	122	463

^a Air concentrations from test case 7.

^b Air concentrations from test case 8.

^c Air concentrations from test case 9.

calculations were taken from the RESRAD-BUILD manual (Appendix C, Table C.1). The airborne concentration of each radon decay product was then calculated as the sum of the respective concentrations in the free and attached state.

Table 5.2 provides the RESRAD-BUILD and spreadsheet calculated values of the air concentration for the three sets of parameters (default, lower bound, and upper bound) for the one-room air quality model. The air concentrations for Ra-226 and Th-228 are from Figure 4.1. For calculating air concentrations, density differences were taken into consideration. No significant differences in the RESRAD-BUILD and spreadsheet calculations were observed.




FIGURE 5.3 Air Concentrations for Ra-226 and Th-228 Progeny for a Point Source

WL: working level

$$WL = (\text{variable} * C12) + (\text{variable} * C13) + (\text{variable} * C14)$$

$$4.464E-12 = (1.03E-06 * 2.92E-06) + (5.07E-06 * 2.65E-07) + (3.73E-06 * 3.12E-08)$$

WL (Ra-226) variable(C12) C12 (pCi/m³) variable(C13) C13 (pCi/m³) variable(C14) C14 (pCi/m³)

Radon-220 Ra-226 4.46E-12
Th-228 3.35E-10

WLM: working level month

$$WLM = (8760 / 170) * FIN * FI * WL$$

$$1.15E-10 = (8760 / 170) * 0.5 * 1 * 4.46E-12$$

WLM (Ra-226) (h/yr) (h/month) FIN FI WL

Radon-220 Ra-226 8.62E-09
Th-228 1.15E-10

FIGURE 5.3 (Cont.)

6 TRITIUM MODEL FOR VOLUME SOURCE

Tritium contamination requires special consideration, because in addition to erosion, tritium, which most often is in the chemical form of tritiated water (HTO), can vaporize and escape from the source material. The potential release of tritium from a volume source would occur through erosion and, if in the form of HTO, vaporization. The total release rate is the sum of the releases from erosion and vaporization. The total release rate is then used to calculate the inhalation pathway dose for a tritium volume source. The release rate from erosion is the same as Equation 3.1 for other radionuclides but is modified by a fraction $(1 - f_{rel})$, where f_{rel} is the fraction of tritium available for vaporization. For tritium in a chemical form other than HTO, which is assumed to be released by absorbing or adsorbing to the source material and not by vaporization, the value of f_{rel} would be zero. Similarly, direct ingestion pathway doses would be modified by $(1 - f_{rel})$.

The tritium transport model in RESRAD-BUILD, which was adapted from the land-farming model developed by Thibodeaux and Hwang (1988) estimates the injection rate of HTO molecules into the indoor air from vaporization. The model assumes that the water containing HTO may penetrate into the building walls or floor or equipment and be distributed homogeneously within a depth of h (cm) to h_p (cm) from the surface within the material. The region where the water is distributed is called the wet zone; the dry zone is the region between the wet zone and the air interface. To calculate the release rate of tritium, q_{H3} , at any time from vaporization into the air, the water diffusion rate, q_{water} , at that time needs to be multiplied by the activity concentration of tritium in water, A_{H3} , and radiological decay. The release q_{H3} can be given as:

$$q_{H3} = 3,600 A_{H3} e^{-\lambda t'} q_{water}, \quad (6.1)$$

where

q_{H3} = release rate of tritium at time t' (pCi/h),

A_{H3} = activity concentration of tritium in water at time zero (pCi/g),

λ = radiological decay constant of tritium (1/yr),

t' = elapsed time since the beginning of the vaporization process (yr), and

3,600 = conversion factor of time (s/h).

The activity concentration of tritium in water is related to the activity concentration of tritium in the contaminated zone as:

$$A_{H3} = C_{H3} \left(1 + \frac{\rho_b}{\rho_{water} W} \right), \quad (6.2)$$

where

C_{H3} = activity concentration of tritium in the contaminated zone (pCi/g),

ρ_b = bulk density of the porous material (g/cm³),

W = moisture content (volumetric water content) in the wet zone (dimensionless), and

ρ_{water} = density of water (g/cm³).

Under the steady-state assumption, the vaporization rate from the wet zone is equivalent to the diffusion rate from the dry zone and is given as:

$$q_{water} = \frac{D_e C'_g A_s}{\sqrt{h_s^2 + \frac{2D_e C'_g t' f_{time}}{C_s f_{rel}}}}, \quad (6.3)$$

where

f_{time} = conversion factor (31,557,600 s/yr),

C_s = mass concentration of water in the wet zone (g/cm³),

C'_g = concentration of water molecules in the vapor phase of the source material (g/cm³),

h_s = dry zone thickness at the beginning of time ($t = 0$) (cm),

D_e = effective diffusion coefficient of water molecules in the source material (cm²/s), and

A_s = surface area of the source (cm²).

$$C_s = W \rho_{water}, \quad (6.4)$$

$$C'_g = (C_g - C_{g,amb}), \quad (6.5)$$

where

C_g = concentration of water vapor in the void space of the wet zone (g/cm^3) and

$C_{g,amb}$ = absolute humidity in the air (g/cm^3).

$$D_e = D_l n^{\frac{4}{3}}, \quad (6.6)$$

where

n = total porosity and

D_l = air diffusion coefficient ($0.2444 \text{ cm}^2/\text{s}$).

$$C_g = \frac{P_{sat} MW}{RT}, \quad (6.7)$$

where

MW = molecular weight of water ($18 \text{ g}/\text{mol}$),

R = the gas constant [$82(\text{atm} \times \text{cm}^3)/\text{mol} \times \text{K}$],

T = room temperature (298 K), and

P_{sat} = saturated vapor pressure of water (0.0245 atm).

The RESRAD-BUILD tritium model estimates the average release rate of tritium over a certain time period. The time period is the smallest of three: one year, exposure duration, or the time required for the remaining free water to vaporize. The time required for the remaining free water in the wet zone to vaporize depends on the thickness of the dry zone (h) (a layer on top of the wet zone) and the wet zone ($h_p - h$). The dry zone can be considered as a layer without any H-3 concentration, and the wet zone is where H-3 is available for vaporization. According to Fick's law, the diffusion rate of H_2O molecules through the dry zone can be expressed as:

$$q_{water} = \frac{D_e (C_g - C_{g,amb})}{h} A_s \cdot \quad (6.8)$$

Under steady-state conditions, the vaporization rate from the wet zone is equivalent to the diffusion rate through the dry zone. Therefore,

$$q_{water} = A_s C_s f_{rel} \frac{dh}{dt}. \quad (6.9)$$

Using Equations 6.8 and 6.9, the dry zone thickness at any time t can be calculated by the following equation:

$$h = \sqrt{h_s^2 + \frac{2 D_e (C_g - C_{g,amb}) t}{C_s f_{rel}}}. \quad (6.10)$$

The time required for the remaining free water in the wet zone to vaporize, t_d , can be calculated after setting h to h_p and h_s to h in Equation 6.10 as:

$$t_d = \frac{C_s (h_p^2 - h^2) f_{rel}}{2 D_e C'_g}. \quad (6.11)$$

The Newton-Cotes open integration method is used to estimate the average release rate of tritium. Five equally spaced time points are selected over the time period (t_{period}) for which the instantaneous release rate of tritium is estimated. The average release rate is then obtained by summing the weighted spontaneous release rates for the five time points, as represented by the following equation:

$$q_{H3,avg} = \frac{11q_{H3}^1 - 14q_{H3}^2 + 26q_{H3}^3 - 14q_{H3}^4 - 11q_{H3}^5}{20}, \quad (6.12)$$

where

$q_{H3,avg}$ = average release rate of tritium over the time period (pCi/yr),

t_{period} = time period (yr),

$q_{H3}^1, q_{H3}^2, q_{H3}^3, q_{H3}^4, q_{H3}^5$ = instantaneous tritium release rates at time points t^1, t^2, t^3, t^4, t^5 , respectively, and

t^1, t^2, t^3, t^4, t^5 = selected time points for estimating the instantaneous release rate, evenly distributed between t and $t + t_{period}$.

Figure 6.1 shows all tritium-model parameters required for a volume source and the calculation of the average tritium release rate. The average tritium release rate calculated from vaporization is added to the release rate from the source erosion for a volume source (Equation 3.1) to calculate the inhalation pathway dose for the tritium volume source (Section 8.8).

Tritium Model	
$Cs = W \cdot P_{water}$	$= (Eq. 6.4) \quad 3.00E-02 \cdot 1 \cdot P_{water}$ (g/cm ³) (cm ³ /cm ³) (g/cm ³)
$Cs =$	$3.00E-02$ (g/cm ³)
$T1(yr) = t_{period}$	$= 6$ (yr)
$T1 =$	$6.96E-02$ (yr)
$T1 = (P_{sat}/R) \cdot (mw/T)$	$= (Eq. 6.7) \quad 82 \cdot 18 \cdot 298$ (atm.cm ³)/(mol.K) (g/mol) (K)
$Cg =$	$2.45E-02$ (atm)
$Cg1 = (Cg - Cg1_{amb})$	$= (Eq. 6.5) \quad 1.80E-05$ (g/cm ³)
$Cg1 =$	$1.80E-05$ (g/cm ³)
$De = DI \cdot (n^{4/3})$	$= (Eq. 6.6) \quad 2.44E-01$ (cm ² /s)
$De =$	$1.13E-02$ (cm ² /s)
AHS: activity concentration of porous material = $CH3 \cdot (1 + (Pb / (P_{water} \cdot W)))$ (Eq. 6.2)	
$AHS =$	$8.10E+01$ (pCi/g)
$q_{water} = (De \cdot Cg1 \cdot As) / \sqrt{(hs^2 + (2 \cdot De \cdot Cg1 \cdot t \cdot t_{ime}) / Cs \cdot f_{rel})}$ (Eq. 6.3)	
$q_{water}(T1) =$	$1.01E-02$ (g/s)
$q_{water}(T2) =$	$7.11E-03$ (g/s)
$q_{water}(T3) =$	$5.80E-03$ (g/s)
$q_{water}(T4) =$	$5.03E-03$ (g/s)
$q_{water}(T5) =$	$4.49E-03$ (g/s)

FIGURE 6.1 Tritium Model Intermediate Calculations for the Injection Rate from Vaporization and the Average Release Rate from the Tritium Volume Source from Volatization




FIGURE 6.1 (Cont.)

7 EXTERNAL EXPOSURE MODEL

In the RESRAD-BUILD code, two direct exposure models based on the geometrical type of sources are used. The first model for area and volume sources is based on a semi-infinite slab source with corrections for geometrical factors. The second model for point and line contamination is a simple dose integral method. The doses from the point and line sources were calculated as described in Sections F.3 and F.4 of the RESRAD-BUILD manual (Yu et al. 1994), respectively.

The external dose for the volume and area sources depends upon the geometry of the source relative to the point where the dose is to be evaluated. In RESRAD-BUILD, the volume source can have up to five layers, and the contamination can be in any of the layers. The source geometry is specified by the source location, source parameters (area, thickness, and density), receptor location, and the shielding thickness between the source and the receptor. The exposure model uses the external DCFs from Federal Guidance Report No. 12 (FGR-12) (Eckerman and Ryman 1993), which include dose contributions from gamma and beta radiation. The methodology described by Kamboj et al. (1998) for corrections due to finite size was extended to include differences due to the source material.

For calculating external exposure from deposited material, only floor deposition was considered and was treated as an area source. The exposure to the receptor was from the deposition in the same room as the receptor only. For example, the receptor in room 1 would be exposed to the deposition in room 1 and would not be exposed to deposition in any other room. Similarly, for the air submersion pathway, the exposure to the receptor was from the radioactive air concentration in the same room as the receptor.

The external pathway dose from exposure to an area or a volume source containing radionuclide n in compartment I , D_{iv}^n , is expressed as:

$$D_{iv}^n = F_{in} F_i C_s^n DCF_v^n F_G^n, \quad (7.1)$$

where

F_{in} = fraction of time spent indoors;

F_i = fraction of time spent in compartment i ;

DCF_v^n = FGR-12 dose conversion factor for infinite volume source; and

F_G^n = geometrical factor for finite area, source thickness, shielding, source material, and position of receptor relative to the source for radionuclide n .

The geometrical factor, F_G , is the ratio of the effective dose equivalent for the actual source to the effective dose equivalent for the standard source. The standard source is a contaminated soil of infinite depth and lateral extent with no cover. The geometrical factor is expressed as the product of the depth-and-cover factor, F_{CD} , an area and material factor, F_{AM} , and the off-set factor, $F_{OFF-SET}$.

Dose conversion factors in FGR-12 (Eckerman and Ryman 1993) are given for surface and uniformly distributed volume sources at four specific thicknesses (1, 5, and 15 cm, and effectively infinite) with a soil density of 1.6 g/cm^3 . FGR-12 assumes that sources are infinite in lateral extent. In actual situations, sources can have any depth, shape, cover, and size. A depth-and-cover factor function, F_{CD} , was developed with regression analysis to express the attenuation for radionuclides. Three independent radionuclide-specific parameters were determined by using the effective dose equivalent values of FGR-12 at different depths. Kamboj et al. (1998) describes how the depth-and-cover function was derived using the effective dose equivalent values of FGR-12 at different depths. A depth-and-cover factor function was derived from the depth factor function by considering both dose contribution and attenuation from different depths:

$$\frac{D(T_c = t_c, T_s = t_s)}{D(T_c = 0, T_s = \infty)} = Ae^{-K_A \rho_c t_c} (1 - e^{-K_A \rho_s t_s}) + Be^{-K_B \rho_c t_c} (1 - e^{-K_B \rho_s t_s}), \quad (7.2)$$

where

A, B = fit parameters (dimensionless);

K_A, K_B = fit parameters (cm^2/g);

t_c = shielding thickness (cm) (the sum of all shielding thicknesses between the source and the receptor), the shielding is placed immediately adjacent to the source;

ρ_c = shielding density (g/cm^3) (the thickness-averaged density between the source and receptor);

t_s = source thickness (cm);

ρ_s = source density (g/cm³);

T_c = shielding parameter (m); and

T_s = source depth parameter (m).

The following constraints were put on the four fitting parameters:

1. All the parameters were forced to be positive;
2. $A + B = 1$; and
3. In the limit source depth, $t_s \rightarrow$ zero, the DCF should match the contaminated surface DCF.

All the four unknown parameters (A , B , K_A , and K_B) were found for 67 radionuclides available in the RESRAD-BUILD computer code. The fitted values of A , B , K_A , and K_B for radionuclides were used in the dose calculations.

For actual geometries (finite area and different materials), the area and material factor, F_{AM} , was derived by using the point-kernel method. This factor depends not only on the lateral extent of the contamination but also on source thickness, shielding thickness, gamma energies, and source material through its attenuation and buildup factors. All energies from radionuclide decay were considered separately and weighted by its yield, y , energy, E , and an energy-dependent coefficient, K , to convert from air-absorbed dose to effective dose equivalent:

$$F_{AM} = \frac{\sum_{\text{Energies: } j} y_j E_j K_j \int_{V'} \frac{B(x') e^{-\mu x'}}{(x')^2} dV}{\sum_{\text{Energies: } j} y_j E_j K_j \int_V \frac{B(x) e^{-\mu x}}{(x)^2} dV}, \quad (7.3)$$

where

$$(x')^2 = r^2 + (t_a + t_c + t)^2, \quad (7.4)$$

$$(x)^2 = r^2 + (1m + t)^2 \quad (7.5)$$

$$\mu = \frac{(t_a \mu_a + t_c \mu_c + t \mu_s)}{(t_a + t_c + t)}, \text{ and} \quad (7.6)$$

$$B(x) = B_a \left(\frac{t_a}{t_a + t_c + t_s} x \right) B_c \left(\frac{t_c}{t_a + t_c + t_s} x \right) B_s \left(\frac{t_s}{t_a + t_c + t_s} x \right). \quad (7.7)$$

B and μ are the buildup factor and the attenuation factor, respectively, for the appropriate material (a for air, c for shield material, and s for source material or soil reference). The integration volume V' is the desired geometry of specified material with radius R , shielding thickness t_c , and air thickness t_a ; whereas V is the reference geometry of soil extending infinitely laterally with no shield and the receptor midpoint located 1 m from the surface.

The off-set factor, $F_{OFF-SET}$, is the ratio of the dose estimates from a noncircular shaped contaminated material to a reference shape. The concept of the shape factor is used to calculate the off-set factor. The reference shape is a fully contaminated circular area encompassing the given shape, centered about the receptor. This factor is derived by considering the area, material factors of a series of concentric circles, and the corresponding contamination fraction of the annular regions. The off-set factor is obtained by enclosing the irregularly shaped contaminated area in a circle, multiplying the area factor of each annulus by the fraction of the contaminated annulus area, f_i , summing the products, and dividing by the area factor of a circular contaminated material that is equivalent in area:

$$F_{OFF-SET} = \frac{\sum_{i=0}^n f_i [F_A(A_i) - F_A(A_{i-1})]}{F_A \left[\sum_{i=0}^n f_i (A_i - A_{i-1}) \right]}. \quad (7.8)$$

Because RESRAD-BUILD does not give intermediate results (i.e., geometrical, depth-and-cover, area and material, and off-set factors) for the external exposure pathway, only the pathway doses were compared with the spreadsheet results in Section 8.6. The results of the external exposure models (point and line sources and area and volume sources) were also benchmarked with those from the MCNP transport code. For this comparison, MCNP version 4A was used.

The point source dose was compared at three receptor distances (15, 100, and 1,000 cm) for three radionuclides: Co-60 (1.25 MeV, gamma abundance 200%), Mn-54 (836 keV, gamma abundance 100%), and Au-195 (71.6 keV, gamma abundance 110%) to cover different energy sources. Table 7.1 presents the comparison of the RESRAD-BUILD calculated results with the MCNP calculations. All results are within 5% of each other.

TABLE 7.1 Point Source Dose ([mrem/yr]/pCi) Comparison between RESRAD-BUILD^a and MCNP

Radionuclide	Receptor Distances (cm)					
	15		100		1,000	
	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP
Au-195	1.24E-05	1.24E-05	2.86E-07	2.84E-07	3.57E-09	3.33E-09
Mn-54	1.31E-04	1.32E-04	2.95E-06	2.96E-06	2.91E-08	2.91E-08
Co-60	3.72E-04	3.72E-04	8.36E-06	8.35E-06	8.25E-08	8.17E-08

^a Point source external exposure pathway dose from test case 10.

The line source dose was compared at three receptor distances (10, 100, and 1,000 cm) for the same three radionuclides as was used for the point source comparison. The comparison was performed for line sources of four different lengths (1, 10, 100, and 1,000 cm). Table 7.2 presents the comparison of the RESRAD-BUILD calculated results with the MCNP calculations. All results are within 1% of each other.

The area source dose was compared at three receptor distances (15, 100, and 1,000 cm) for the same three radionuclides as were used for the point source comparison. The comparison was performed for a source area of 3.2 m². Table 7.3 presents the comparison of the RESRAD-BUILD calculated results with the MCNP calculations. All results are within 5% of each other.

The volume source dose was compared at three receptor distances (15, 100, and 1,000 cm) for Au-195, Mn-54, and Co-60. The comparison was performed for a source density of 2.4 g/cm³, an area of 3.2 m², and three thicknesses (1, 10, and 50 cm). Table 7.4 presents the comparison of the RESRAD-BUILD calculated results with the MCNP calculations with agreement within 20%. The comparison includes the area and material factor, off-set factor, and depth-and-cover factor.

The external exposure model was also compared with MCNP calculations for RESRAD-BUILD default parameter values for point, line, surface, and volume sources. The radionuclides used in this comparison were the same as before (Au-195, Mn-54, and Co-60) to cover a wide energy range. Table 7.5 presents the comparison of the values from RESRAD-BUILD code output and MCNP code calculations. The results of the RESRAD-BUILD code for case 10a are provided in the Appendix. The results match within 1% for point sources, within 5% for line and area sources, and within 10% for volume source for all radionuclides. For higher energy radionuclides, Mn-54 and Co-60, the results agree within 3%.

TABLE 7.2 Line Source Dose ([mrem/yr]/[pCi/m]) Comparison between RESRAD-BUILD^a and MCNP

Radionuclide	Receptor Distances (cm)					
	10		100		1,000	
	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP
Line source length = 1 cm						
Au-195	2.79E-07	2.77E-07	2.86E-09	2.84E-09	3.57E-11	3.33E-11
Mn-54	2.95E-06	2.96E-06	2.95E-08	3.02E-08	2.91E-10	2.91E-10
Co-60	8.37E-06	8.36E-06	8.36E-08	8.34E-08	8.25E-10	8.18E-10
Line source length = 10 cm						
Au-195	2.59E-06	2.57E-06	2.85E-08	2.84E-08	3.57E-10	3.33E-10
Mn-54	2.74E-05	2.75E-05	2.95E-07	2.96E-07	2.91E-09	2.91E-09
Co-60	7.77E-05	7.76E-05	8.35E-07	8.34E-07	8.25E-09	8.18E-09
Line source length = 100 cm						
Au-195	7.67E-06	7.63E-06	2.65E-07	2.64E-07	3.57E-09	3.32E-09
Mn-54	8.11E-05	8.11E-05	2.73E-06	2.74E-06	2.91E-08	2.90E-08
Co-60	2.30E-04	2.29E-04	7.75E-06	7.74E-06	8.22E-08	8.18E-08
Line source length = 1,000 cm						
Au-195	8.64E-06	8.63E-06	7.73E-07	7.89E-06	3.28E-08	3.13E-08
Mn-54	9.15E-05	9.16E-05	8.05E-06	8.12E-06	2.69E-07	2.70E-07
Co-60	2.59E-04	2.58E-04	2.29E-05	2.28E-05	7.63E-07	7.60E-07

^a Line source external exposure pathway dose from test case 13.

TABLE 7.3 Area Source Dose ([mrem/yr]/[pCi/m²]) Comparison between RESRAD-BUILD^a and MCNP

Radionuclide	Receptor Distances (cm)					
	15		100		1,000	
	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP
Au-195	3.16E-06	3.37E-06	5.88E-07	6.18E-07	1.06E-08	1.04E-08
Mn-54	3.41E-05	3.57E-05	6.23E-06	6.46E-06	8.89E-08	9.20E-08
Co-60	9.70E-05	1.01E-04	1.78E-05	1.82E-05	2.53E-07	2.56E-07

^a Area source external exposure pathway dose from test case 11.

TABLE 7.4 Volume Source Dose ([mrem/yr]/[pCi/m]) Comparison between RESRAD-BUILD^a and MCNP

Radionuclide	Receptor Distances (cm)					
	15		100		1,000	
	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP
Source thickness = 1 cm						
Au-195	0.0688	0.0684	0.0146	0.0176	2.15E-04	2.85E-04
Mn-54	0.758	0.848	0.143	0.173	0.00206	0.00249
Co-60	2.12	2.38	0.402	0.472	0.00579	0.00673
Source thickness = 10 cm						
Au-195	0.135	0.142	0.0463	0.0506	7.39E-04	8.94E-04
Mn-54	3.80	3.57	1.03	1.10	0.0161	0.0179
Co-60	11.4	10.9	3.01	3.20	0.0469	0.0510
Source thickness = 50 cm						
Au-195	0.133	0.146	0.0459	0.0516	7.35E-04	9.15E-04
Mn-54	4.12	4.28	1.34	1.45	0.0236	0.0254
Co-60	12.7	13.6	4.07	4.53	0.0727	0.0803

^a Volume source external exposure pathway dose from test case 12.

TABLE 7.5 Direct External Exposure Pathway Dose (mrem/yr) Comparison between RESRAD-BUILD^a and MCNP Using Default Parameters

Radionuclide	Point		Line		Area		Volume	
	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP	RESRAD-BUILD	MCNP
Au-195	4.85E-08	4.80E-08	2.94E-07	3.10E-07	1.01E-06	1.08E-06	0.0534	0.0596
Mn-54	4.91E-07	4.93E-07	3.07E-06	3.10E-06	1.05E-05	1.10E-05	1.64	1.60
Co-60	1.39E-06	1.39E-06	8.72E-06	8.74E-06	3.00E-05	3.10E-05	4.98	4.89

^a External exposure pathway dose from test case 10a.

8 DIFFERENT PATHWAY DOSES

This section discusses the comparison of the different pathway doses calculated by the RESRAD-BUILD code with the spreadsheet calculations. Individual pathway doses for a single radionuclide were compared first, followed by a comparison of the total receptor dose. The RESRAD-BUILD code generated output files — `diag.out` and `resradb.rpt` — for all 17 cases are provided in the Appendix. Table 2.3 lists all the relevant files used in each verification calculation.

8.1 SUBMERSION PATHWAY

The air submersion external dose from exposure to indoor contaminated air was calculated by using the following equation (Yu et al. 1994, Equation F.13):

$$D_{i,sub}^n(t) = F_{in} F_i C_i^n(t) DCF_{sub}^n, \quad (8.1)$$

where

$D_{i,sub}^n(t)$ = total annual air submersion effective dose equivalent from radionuclide n at time t in compartment i (mrem/yr);

$C_i^n(t)$ = average concentration of radionuclide n at time t in the indoor air of compartment i (pCi/m³); and

$DCF_{sub}^n(t)$ = air submersion DCF for radionuclide n (mrem/yr per pCi/m³).

Figure 8.1 shows the spreadsheet calculations for the default parameter set. The air concentration, C_{IN}, in Figure 8.1 is from the calculated air concentration in Figure 4.1 for the volume source. Table 8.1 provides the RESRAD-BUILD and spreadsheet calculated values of the submersion pathway doses for the three sets of parameters for the one-room model. The doses were compared for volume, area, line, and point sources. The comparison was performed for Na-22 and Al-26 at time zero, with excellent agreement between the code output and spreadsheet verification.




FIGURE 8.1 Air Submersion Pathway Dose Calculations

TABLE 8.1 RESRAD-BUILD and Spreadsheet Submersion Pathway Dose (mrem/yr) Values for Three Sets of Input Parameters

Source Type	Default ^a		Lower ^b		Upper ^c	
	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet
Na-22						
Volume	5.83E-09	5.82E-09	1.72E-11	1.72E-11	8.97E-06	8.96E-06
Area	1.39E-08	1.38E-08	9.82E-11	9.81E-11	1.28E-09	1.28E-09
Line	1.39E-08	1.38E-08	9.82E-11	9.81E-11	1.28E-09	1.28E-09
Point	3.85E-10	3.84E-10	2.73E-11	2.72E-11	3.56E-12	3.55E-12
Al-26						
Volume	9.55E-09	9.54E-09	2.17E-11	2.17E-11	1.13E-05	1.13E-05
Area	2.27E-08	2.27E-08	1.24E-10	1.24E-10	1.62E-09	1.61E-09
Line	2.27E-08	2.27E-08	1.24E-10	1.24E-10	1.62E-09	1.61E-09
Point	6.31E-10	6.30E-10	3.44E-11	3.44E-11	4.49E-12	4.48E-12

^a Submersion pathway dose from test case 1.

^b Submersion pathway dose from test case 2.

^c Submersion pathway dose from test case 3.

8.2 INADVERTENT INGESTION DIRECTLY FROM THE SOURCE

The component of the effective dose equivalent due to ingestion of loose material directly from the volume source in compartment i containing radionuclide n was calculated by using the following equation (Yu et al. 1994, Equation E.1):

$$D_{il}^n(t) = (8,760 F_{in} F_i) ER C_s^n(t) DCF_g^n \quad (8.2)$$

where

$D_{il}^n(t)$ = annual component of the total effective dose equivalent due to ingestion of loose material directly from the source containing radionuclide n at time t in compartment i (mrem/yr);

8,760 = time conversion factor (number of hours per year) (h/yr);

F_{in} = fraction of time spent indoors (dimensionless);

F_i = fraction of indoor time spent at compartment i (dimensionless);

ER = ingestion rate of loose material directly from the source (g/h);

$C_s^n(t)$ = average concentration of radionuclide n in the source material (pCi/g) at time t ; and

DCF_g^n = ingestion DCF related to radionuclide n (mrem/pCi).

Surface, line, and point sources, for compartment i can be calculated with the following equation (Yu et al. 1994, Equation E.2):

$$D_{ij}^n(t) = (8,760 F_{in} F_i) ER_l f_R Q_s^n(t) DCF_g^n, \quad (8.3)$$

where

f_R = removable fraction of the source material;

ER_l = ingestion rate of loose material directly from the source as a fraction of the source per unit time (1/h); and

$Q_s^n(t)$ = average total radionuclide activity in the source (pCi) at time t .

Figure 8.2 shows the spreadsheet calculations for the upper bound parameter set. Table 8.2 provides the RESRAD-BUILD and spreadsheet calculated values of the inadvertent ingestion pathway doses for the three sets of parameters for the one-room model. The doses were compared for volume, area, line, and point sources. The comparison was performed for Na-22 and Al-26 at time zero; again, excellent agreement was obtained between the code output and the spreadsheet results. The direct inadvertent ingestion pathway dose for lower bound and default parameters is zero because of the zero direct ingestion rate.




FIGURE 8.2 Inadvertent Ingestion Pathway Dose Directly from the Source

TABLE 8.2 RESRAD-BUILD and Spreadsheet Direct Inadvertent Ingestion Pathway Dose (mrem/yr) Values for Three Sets of Input Parameters

Source Type	Default ^a		Lower ^b		Upper ^c	
	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet
Na-22						
Volume	0.0	0.0	0.0	0.0	2.52E-04	2.52E-04
Area	0.0	0.0	0.0	0.0	9.07E-04	9.07E-04
Line	0.0	0.0	0.0	0.0	9.07E-04	9.07E-04
Point	0.0	0.0	0.0	0.0	2.52E-06	2.52E-06
Al-26						
Volume	0.0	0.0	0.0	0.0	3.20E-04	3.20E-04
Area	0.0	0.0	0.0	0.0	1.15E-03	1.15E-03
Line	0.0	0.0	0.0	0.0	1.15E-03	1.15E-03
Point	0.0	0.0	0.0	0.0	3.20E-06	3.20E-06

^a Direct inadvertent ingestion pathway dose from test case 1-DI.

^b Direct inadvertent ingestion pathway dose from test case 2-DI.

^c Direct inadvertent ingestion pathway dose from test case 3-DI.

8.3 INADVERTENT INGESTION OF DEPOSITED MATERIALS

The component of the effective dose equivalent due to ingestion of radioactive dust particulates deposited onto surfaces was calculated by using the following equation:

$$D_{id}^n(t) = (8,760 F_{in} F_i) SER C_{di}^n(t) DCF_g^n, \quad (8.4)$$

where

$D_{id}^n(t)$ = annual component of the total effective dose equivalent, due to ingestion of deposited dust particulates containing radionuclide n in compartment i at time t (mrem/yr);

8,760 = time conversion factor (number of hours per year) (h/yr);

F_{in} = fraction of time spent indoors (dimensionless);

F_i = fraction of indoor time spent at compartment i (dimensionless);

SER = surface ingestion rate or the ingestion rate of dust particulates deposited onto horizontal surfaces (m^2/h);

$C_{di}^n(t)$ = average surface concentration of radionuclide n , deposited onto horizontal surfaces of compartment i (pCi/m^2) at time t ; and

DCF_g^n = ingestion DCF for radionuclide n ($mrem/pCi$).

Figure 8.3 shows the spreadsheet calculations for the default parameter set. The surface concentration from deposition, CDIN, in Figure 8.3 is from the calculated surface concentration in Figure 4.5 for the volume and point sources. Table 8.3 provides the RESRAD-BUILD and spreadsheet calculated values of the inadvertent ingestion of deposited material pathway doses for the three sets of parameters for the one-room model. The doses were compared for volume, area, line, and point sources. The comparison was performed for Na-22 and Al-26 at time zero. The spreadsheet verification results matched the code output.

8.4 DOSE FROM INHALATION OF AIRBORNE RADIOACTIVE PARTICULATES

The committed effective dose equivalent due to inhalation of radionuclides in the indoor air of compartment i was calculated by using the following equation (Yu et al. 1994, Equation D.3):

$$D_{ih}^n(t) = (365 F_{in} F_i) IR C_i^n(t) DCF_h^n, \quad (8.5)$$

where

$D_{ih}^n(t)$ = annual total effective dose equivalent due to inhalation of radionuclide n at time t in compartment i ($mrem/yr$);

365 = time conversion factor (number of days per year) (d/yr);

F_{in} = fraction of time spent indoors (dimensionless);




FIGURE 8.3 Inadvertent Ingestion Pathway Dose Directly from Materials Deposited on Surfaces

TABLE 8.3 RESRAD-BUILD and Spreadsheet Dose (mrem/yr) Values for the Inadvertent Ingestion of Deposited Material for Three Sets of Input Parameters

Source Type	Default ^a		Lower ^b		Upper ^c	
	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet
Na-22						
Volume	9.15E-08	9.15E-08	0.0	0.0	1.97E-05	1.97E-05
Area	2.18E-07	2.18E-07	0.0	0.0	2.81E-09	2.81E-09
Line	2.18E-07	2.18E-07	0.0	0.0	2.81E-09	2.81E-09
Point	6.05E-09	6.05E-09	0.0	0.0	7.81E-12	7.81E-12
Al-26						
Volume	1.53E-07	1.53E-07	0.0	0.0	2.50E-05	2.50E-05
Area	3.65E-07	3.65E-07	0.0	0.0	3.57E-09	3.57E-09
Line	3.65E-07	3.65E-07	0.0	0.0	3.57E-09	3.57E-09
Point	1.01E-08	1.01E-08	0.0	0.0	9.91E-12	9.91E-12

^a Inadvertent ingestion of deposited material dose from test case 1.

^b Inadvertent ingestion of deposited material dose from test case 2.

^c Inadvertent ingestion of deposited material dose from test case 3-II.

F_i = fraction of indoor time that is spent at compartment i (dimensionless);

IR = inhalation rate (m^3/d);

$C_i^n(t)$ = average concentration of radionuclide n (pCi/m^3) at time t in the indoor air of compartment i ; and

$DCF_n^i(t)$ = inhalation DCF for radionuclide n (mrem/pCi).

Figure 8.4 shows the spreadsheet calculations for the default parameter set for the volume and area sources. The air concentration, C_{1N} , in Figure 8.4 is from the calculated air concentration in Figure 3.1 for the volume and area sources. Table 8.4 provides the RESRAD-BUILD and spreadsheet calculated values of the inhalation pathway doses for the three sets of parameters for the one-room model. The doses were compared for volume, area, line, and point sources. The comparison was performed for Na-22 and Al-26 at time zero. The spreadsheet calculation results were found to match those in the code output.




FIGURE 8.4 Inhalation Pathway Dose Calculations

TABLE 8.4 RESRAD-BUILD and Spreadsheet Inhalation Pathway Dose (mrem/yr) Values for Three Sets of Input Parameters

Source Type	Default ^a		Lower ^b		Upper ^c	
	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet
Na-22						
Volume	2.32E-08	2.32E-08	4.58E-11	4.58E-11	9.06E-05	9.06E-05
Area	5.53E-08	5.53E-08	2.61E-10	2.61E-10	1.29E-08	1.29E-08
Line	5.53E-08	5.53E-08	2.61E-10	2.61E-10	1.29E-08	1.29E-08
Point	1.54E-09	1.54E-09	7.25E-11	7.25E-11	3.59E-11	3.59E-11
Al-26						
Volume	3.14E-07	3.14E-07	4.76E-10	4.76E-10	9.42E-04	9.42E-04
Area	7.46E-07	7.46E-07	2.71E-09	2.71E-09	1.34E-07	1.34E-07
Line	7.46E-07	7.46E-07	2.71E-09	2.71E-09	1.34E-07	1.34E-07
Point	2.07E-08	2.07E-08	7.54E-10	7.54E-10	3.73E-10	3.73E-10

^a Inhalation pathway dose from test case 1.

^b Inhalation pathway dose from test case 2.

^c Inhalation pathway dose from test case 3.

8.5 DOSE FROM INHALATION OF AEROSOL INDOOR RADON PROGENY

Table 8.5 provides the RESRAD-BUILD and spreadsheet calculated values of the radon inhalation pathway doses for the three sets of parameters for the one-room model. The doses were compared for volume and point sources. For surface, area, and point sources, dose only depends on the total source concentration, irrespective of the source type. The comparison was performed for Ra-226 and Th-228 at time zero to check the doses from Rn-222 and Rn-220 progeny. Figure 8.5 shows the spreadsheet calculations for the radon inhalation pathway dose with the default parameter set for the volume and point sources. Good agreement, to within 1%, was obtained between the code output and the verification check.

8.6 DIRECT EXTERNAL EXPOSURE

To compare doses from direct external exposure, it was assumed that the sources were infinite in lateral extent. The dose from different types of sources that include area and material factor, off-set factor, and depth-and-cover factor was compared with MCNP results in Section 7. Figure 8.6 shows how the doses for the external pathway were calculated for volume and area sources. The calculated results for the volume source were for a large area source (area

TABLE 8.5 RESRAD-BUILD and Spreadsheet Radon Inhalation Pathway Dose (mrem/yr) Values for Ra-226 and Th-228 Sources for Three Sets of Input Parameters

Source Type	Default ^a		Lower ^b		Upper ^c	
	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet	RESRAD-BUILD	Spreadsheet
Ra-226						
Volume	2.27	2.27	3.00	3.00	42.4	42.4
Point	8.75E-08	8.74E-08	4.17E-06	4.16E-06	4.91E-08	4.91E-08
Th-228						
Volume	17.1	16.7	32.4	31.7	3,460	3,390
Point	1.29E-06	1.27E-06	9.22E-05	9.04E-05	5.73E-06	5.61E-06

^a Radon inhalation pathway dose from test case 7.

^b Radon inhalation pathway dose from test case 8.

^c Radon inhalation pathway dose from test case 9.

factor = 1), with the receptor at 1 m from the center of the 15-cm-thick source ($F_{OFF-SET} = 1$). Table 8.6 provides the RESRAD-BUILD and spreadsheet calculated values of the direct external pathway doses for the three sets of parameters (source was of infinite lateral extent). For external exposure only, the source, receptor, and shielding characteristics are required. The receptor is always at a 1-m height from the source for these comparisons. There is no shielding between the source and receptor for the area sources. Good agreement, to within 2%, was obtained between the code output and the spreadsheet verification.

8.7 EXTERNAL EXPOSURE TO DEPOSITED MATERIALS

To compare doses from external exposure to deposited materials, it was assumed that the floor area was infinite in lateral extent (to avoid calculation of the area factor) and that the receptor was at a height of 1 m from the deposited source (a large floor area of 1,000,000 m²). The doses were calculated similar to the direct exposure from area sources. The source concentration was calculated from the deposited materials. Figure 8.7 shows the source deposition and the calculated dose from deposition. Table 8.7 provides the comparison for three input parameter sets. For the lower-bound parameter set, the dose from deposited materials was zero because the deposition velocity was zero (no deposition). Calculated doses were found to agree, within 5%, between the RESRAD-BUILD output and the spreadsheet verification.

Inhalation of Aerosol Indoor Radon Progeny
 For surface, line, and point sources
 D1 (mrem/yr): effective dose equivalent due to exposure to radon decay products
 $D1 = K * WLM * DCF$ (Eq. 5.4)

Rn-220				
1.27E-06	=	4.20E-01	*	8.62E-09
D1(Th-228)		K		WLM
(mrem/yr)				DCF
				(mrem/WLM)
Rn-222				
8.74E-08	=	7.60E-01	*	1.15E-10
D1(Ra-226)		K		WLM
(mrem/yr)				DCF
				(mrem/WLM)
		Rn-220	Rn-222	
		(mrem/yr)	(mrem/yr)	
Ra-226			8.74E-08	
Th-228		1.27E-06		

For one layer volume source

Rn-220				
1.67E+01	=	4.20E-01	*	1.14E-01
D1(Th-228)		K		WLM
(mrem/yr)				DCF
				(mrem/WLM)
Rn-222				
2.27E+00	=	7.60E-01	*	2.98E-03
D1(Ra-226)		K		WLM
(mrem/yr)				DCF
				(mrem/WLM)
		Rn-220	Rn-222	
		(mrem/yr)	(mrem/yr)	
Ra-226			2.27E+00	
Th-228		1.67E+01		

FIGURE 8.5 Radon Pathway Dose Calculations




FIGURE 8.6 Direct External Exposure Pathway Doses from a Volume and Surface Source of a Large Area

TABLE 8.6 RESRAD-BUILD and Spreadsheet Direct External Exposure Pathway Dose (mrem/yr) Values for Three Sets of Input Parameters

Source Type	Default		Lower		Upper	
	RESRAD-BUILD ^a	Spreadsheet	RESRAD-BUILD ^b	Spreadsheet	RESRAD-BUILD ^c	Spreadsheet
Na-22						
Volume	6.67	6.58	1.74	1.72	0.58	0.55
Area	1.22E-04	1.23E-04	5.00E-05	5.03E-05	2.44E-04	2.45E-04
Al-26						
Volume	8.33	8.24	2.08	2.07	0.979	0.926
Area	1.43E-04	1.45E-04	5.84E-05	5.94E-05	2.90E-04	2.85E-04

^a Direct external exposure pathway dose from test case 1E.

^b Direct external exposure pathway dose from test case 2E.

^c Direct external exposure pathway dose from test case 3E.

8.8 TRITIUM VOLUME SOURCE

Figure 8.8 shows the total injection rate calculated for a tritium volume source. The release rate from tritium evaporation, $q_{H3_{avg}}$, is from Figure 6.1. The injection rate was used to calculate the tritium air concentration in the room. The tritium air concentration was then used to calculate the inhalation pathway dose and surface deposition. Figure 8.8 shows all the steps involved in these calculations. The indirect ingestion pathway dose was calculated from surface deposition. The direct ingestion pathway calculation is not shown in this figure because the fraction available for evaporation, f_{rel} , is 1 in the default parameter set, which makes the direct ingestion pathway dose equal to zero. The external pathway dose for the tritium source was zero. Table 8.8 shows excellent agreement between the RESRAD-BUILD and the spreadsheet calculated values of the tritium volume source inhalation and ingestion pathway doses for the three sets of parameters for the one-room model. The remaining volatilization time shown in Table 8.8 (printed in the RESRAD-BUILD summary report) was the same as the time required for the remaining water to evaporate. Figure 6.1 shows the spreadsheet calculation of remaining volatilization time.




FIGURE 8.7 External Exposure from Deposited Materials

TABLE 8.7 RESRAD-BUILD and Spreadsheet Dose (mrem/yr) Values from the External Exposure of Deposited Material for Three Sets of Input Parameters

Source Type	Default		Lower		Upper	
	RESRAD-BUILD ^a	Spreadsheet	RESRAD-BUILD ^b	Spreadsheet	RESRAD-BUILD ^c	Spreadsheet
Na-22						
Volume	7.74E-11	8.02E-11	0.0	0.0	1.51E-09	1.57E-09
Area	1.84E-10	1.91E-10	0.0	0.0	2.16E-13	2.24E-13
Line	1.84E-10	1.91E-10	0.0	0.0	2.16E-13	2.24E-13
Point	5.11E-12	5.30E-12	0.0	0.0	6.00E-16	6.22E-16
Al-26						
Volume	1.20E-10	1.25E-10	0.0	0.0	1.77E-09	1.86E-09
Area	2.84E-10	2.98E-10	0.0	0.0	2.53E-13	2.65E-13
Line	2.84E-10	2.98E-10	0.0	0.0	2.53E-13	2.65E-13
Point	7.90E-12	8.27E-12	0.0	0.0	7.02E-16	7.35E-16

^a External exposure of deposited material dose from test case 1ED.

^b External exposure of deposited material dose from test case 2ED.

^c External exposure of deposited material dose from test case 3ED.

8.9 TOTAL DOSE AT A RECEPTOR LOCATION

In RESRAD-BUILD, the total dose received at each receptor location is the sum of all pathway doses at that location. There was no difference between the sum of the individual pathway doses in RESRAD-BUILD and the code calculated total receptor dose.

According to Section 4.3.3.1 of the RESRAD-BUILD manual (Yu et al. 1994), the dose received at a receptor location is the product of the dose rate at the time specified and the time spent at the receptor location. The time spent at a receptor location is the product of three input parameters: total time on-site (exposure duration), fraction of time in the building (indoor fraction), and fraction of time at the receptor location (receptor time in a particular room). The RESRAD-BUILD code output lists the receptor doses received for the exposure duration and the annual dose averaged over exposure duration. If the receptor spends time at two locations in the building, then the total dose for the receptor can be calculated as the sum of the dose at these two locations.

Inhalation Pathway

$$850.2415 \text{ IS1N(H-3) (pCi/h)} = \left(\left(\frac{1.00E+01}{f} \right) \cdot \left(\frac{8.8E-08}{E} \right) \cdot \left(\frac{36}{AS.1} \right) \cdot \left(\frac{2400}{rhoebs} \right) \cdot \left(\frac{1.00E+03}{CSN} \right) \cdot \left(\frac{0}{(1-frel)} \right) \cdot \left(\frac{8.760}{} \right) \right) + \left(\frac{850.24}{qh3avg} \right) \cdot \left(\frac{qh3avg}{} \right) \text{ (Eq. 3.1)}$$

$$1.11E+01 \text{ C1N(H-3) (pCi/m}^3) = \frac{8.50E+02}{IS1N} / \left(\frac{6.42E-06}{lambdaRN} + \frac{14.4}{lambdaD1} - \left(\frac{1.80E-03}{lambdaR} \right) \right) + \left(\frac{6.42E-06}{lambdaRN} + \frac{1.80E-03}{lambdaR} \right) \cdot \left(\frac{90}{vol1} + \frac{72}{flow01} \right) \text{ (Eq. 4.1)}$$

$$3.50E-03 \text{ DIHN(H-3) (mrem/yr)} = \left(\frac{365}{ED} \right) \cdot \left(\frac{0.5}{FIN} \right) \cdot \left(\frac{1}{FI} \right) \cdot \left(\frac{1.11E+01}{CIN} \right) \cdot \left(\frac{1.80E+01}{IR} \right) \cdot \left(\frac{6.40E-08}{DCFHN} \right) \cdot \left(\frac{1.5}{} \right) \text{ (Eq. 8.5 multiplied by 1.5 to include H-3 dermal absorption)}$$

Ingestion Pathway

$$2.21E+05 \text{ CDIN(H-3) (pCi/m}^2) = \left(\frac{36}{ud} \right) / \left(\frac{6.4E-06}{lambdaRN} + \frac{1.80E-03}{lambdaR} \right) \cdot \left(\frac{1.11E+01}{CIN} \right) \cdot \left(\frac{2.21E+05}{CDIN} \right) \cdot \left(\frac{6.40E-08}{DCFHN} \right) \text{ (Eq. 4.13)}$$

$$6.20E-03 \text{ DIDN(H-3) (mrem/yr)} = \left(\frac{8760}{tu/yr} \right) \cdot \left(\frac{0.5}{FIN} \right) \cdot \left(\frac{1}{FI} \right) \cdot \left(\frac{0.0001}{SER} \right) \cdot \left(\frac{2.21E+05}{CDIN} \right) \cdot \left(\frac{6.40E-08}{DCFHN} \right) \text{ (Eq. 8.4)}$$

FIGURE 8.8 Inhalation and Ingestion Pathway Doses for a Tritium Volume Source for the Default Parameter Set

TABLE 8.8 RESRAD-BUILD and Spreadsheet Inhalation and Ingestion Pathway Dose (mrem/yr) Values for the Tritium Volume Source for Three Sets of Input Parameters

Parameter Set	RESRAD-BUILD			Spreadsheet		
	Inhalation	Remaining Vaporization Time (yr)	Ingestion	Inhalation	Remaining Vaporization Time (yr)	Ingestion
Default ^a	3.49E-03	0.417	6.18E-03	3.50E-03	0.417	6.20E-03
Lower ^b	2.83E-04	0.0117	0.0	2.84E-04	0.0117	0.0
Upper ^c	4.43E-03	18.82	4.27E-04	4.43E-03	18.82	4.29E-04

^a Tritium source from test case 1.

^b Tritium source from test case 2.

^c Tritium source from test case 3.


The use of exposure duration in the code was checked. The exposure duration for a short-lived Ra-228 volume source was varied from 730 to 36.5 days, and the receptor dose with the default parameter set was calculated. Radium-228 was chosen because it decays to short-lived Th-228, and the dose changes with exposure duration. Table 8.9 lists doses at time zero for different exposure durations, with and without time integration. The time integration takes into account the Th-228 buildup with time, whereas the instantaneous dose (taken at the start of the exposure period) does not account for the buildup. The RESRAD-BUILD code applies the time integration over the exposure duration and uses the dose for exposure duration to calculate the receptor's average yearly dose. Figure 8.9 shows the estimated dose with and without time integration.

TABLE 8.9 Receptor Dose for Different Exposure Times for the Ra-228 Volume Source

Exposure Duration (d)	Receptor Dose for Exposure Duration		Receptor Yearly Dose Averaged Over Exposure Duration	
	With Time Integration ^a	Without Time Integration ^b	With Time Integration ^a	Without Time Integration ^b
36.5	0.224	0.19	2.25	1.9
100	0.773	0.52	2.82	1.9
365	4.9	1.9	4.9	1.9
730	14.1	3.8	7.03	1.9

^a Test case 14 with varying exposure duration.

^b Test case 15 with varying exposure duration.

**FIGURE 8.9 Estimated Dose with and without Time Integration**

9 TIME DEPENDENCE IN DOSE CALCULATIONS

This section discusses the time dependence in the dose calculations. In Section 8, pathway doses were always calculated by multiplying the instantaneous dose at time zero by the exposure duration.

9.1 TIME INTEGRATION IN RESRAD-BUILD

The RESRAD-BUILD code calculates the time-integrated dose over the exposure duration. The user can specify the number of points for time integration. These points determine the number of time intervals used in the integrations. In version 3.0 of the code, the maximum number of points for time integration is 17.² This aspect of the code was tested for the short-lived Ra-228 radionuclide, which decays to the short-lived Th-228 radionuclide, and also has a dose contribution from the radon inhalation pathway. First, the time-integrated dose at time zero (at the beginning of assessment), with five time integration points for each pathway, was calculated with the code (case 14). The pathway doses were then compared with the dose calculated at different times ($t = 0$, $t = 0.2$, $t = 0.4$, $t = 0.6$, $t = 0.8$, and $t = 1.0$ yr), with one time dose rate calculation (case 15). Table 9.1 presents the comparison of the calculated doses at different times. The RESRAD-BUILD code generated outputs for cases 14 and 15 are provided in the Appendix. For the Ra-228 radionuclide, the calculated dose without time integration is different at $t = 0.0$, $t = 0.2$, $t = 0.4$, $t = 0.6$, $t = 0.8$, and $t = 1.0$ years; the dose increases because of the progeny (Th-228) buildup. However, no significant difference in the time-integrated and the average individual pathway or total dose (obtained by averaging the dose over different time intervals) was observed.

TABLE 9.1 Calculated Dose (mrem/yr) for the Ra-228 Volume Source with Default Parameters^a

Pathway	$t = \text{time-int}$	$t = 0.0$ yr	$t = 0.2$ yr	$t = 0.4$ yr	$t = 0.6$ yr	$t = 0.8$ yr	$t = 1.0$ yr	$t = \text{average}$
External	2.26	1.9	2.06	2.21	2.34	2.45	2.55	2.25
Deposition	2.89E-07	2.57E-07	2.72E-07	2.85E-07	2.96E-07	3.06E-07	3.14E-07	2.88E-07
Immersion	3.41E-09	2.95E-09	3.16E-09	3.35E-09	3.51E-09	3.65E-09	3.77E-09	3.40E-09
Inhalation	1.66E-04	1.77E-05	8.41E-05	1.44E-04	1.99E-04	2.48E-04	2.92E-04	1.64E-04
Radon	2.64	4.52E-14	1.18	2.25	3.21	4.09	4.87	2.60
Ingestion	1.34E-05	1.32E-05	1.33E-05	1.34E-05	1.34E-05	1.34E-05	1.34E-05	1.34E-05
Total	4.90	1.90	3.24	4.46	5.55	6.54	7.42	4.85

^a The calculated dose for $t = \text{time-int}$ is from test case 14; for other times, it is from test case 15.

² In version 3.1 of the RESRAD-BUILD code, the maximum number of integration points has been increased.

9.2 TIME DEPENDENCE OF SOURCE CHARACTERISTICS IN DOSE

The source characteristics change with time because of radioactive decay and in-growth, source erosion, and source life time. The source characteristics that change with time are radionuclide concentration; thickness for a volume source; removable fraction for area, line, and point sources; and dry zone thickness in the case of the tritium volume source. The removable fraction at times later than the source lifetime is zero, which makes the source injection rate equal to zero for area, line, and point sources. Therefore, the air concentration and all pathway doses, except for radon inhalation and direct external exposure pathways, would be zero at that time. This aspect of the code was tested with Co-60, Ra-226, and U-238 sources and was found to be working correctly.

The source erosion rate changes the source thickness with time, which in turn affects the calculated dose for radon and direct external exposure pathway. To test this aspect of the code, the dose was calculated for the Ra-226 volume source of a large area (100,000 m²), with a source erosion rate of 4.8E-3 cm/d at different evaluation times ($t = 0, 1, 2, 3, 4, 5, 6, 7,$ and 8 years). The radionuclide concentration will change because of radionuclide decay, but should not depend on source thickness. The change in the Ra-226 concentration because of radioactive decay in 8 years (Ra-226 half-life = 1,600 years) will be less than 0.4%. The Ra-226 concentration values printed in the summary report in this case (source erosion rate = 4.8E-3 cm/d) changed from 1 pCi/g at time = 0 years to 0.06474 pCi/g at time = 8 years. Table 9.2 shows the Ra-226 concentration printed in the summary report at different times. It appears that change in radionuclide concentration is related to change in source thickness. Table 9.2 shows the source thickness printed in the summary report at different times. However, the calculated pathway doses appear to be correct. The reporting of the incorrect radionuclide concentration in the summary report, which is not used in dose calculations, should be corrected. Table 9.2 shows the RESRAD-BUILD results and compares the external and radon inhalation dose with the results from the spreadsheet calculations. The summary report associated with Case 16 is in the Appendix.

The radioactive decay and in-growth would change the source concentration and would affect all pathways proportionately. This aspect of the code was tested with the U-238 radionuclide, a long-decay chain radionuclide, and the Ra-228 radionuclide, a short half-life (5.76 years) radionuclide that decays to Th-228, which is another short half-life (1.9131 years) radionuclide. The U-238 radionuclide (half-life = 4.468E+09 years) decays to the U-234 radionuclide (half-life = 2.45E+05 years), which decays to the Th-230 radionuclide (half-life = 8.0E+04 years), which decays to the Ra-226 radionuclide (half-life = 1.6E+03 years), which decays to the Pb-210 radionuclide (half-life = 22.3 years), which decays to the stable Pb-206 nuclide. In all, there are four associated radionuclides (U-234, Th-230, Ra-226, and Pb-210) in the U-238 decay chain. All the associated radionuclides in the chain (decay chain radionuclides with a half-life less than six months) were not included in the discussion above. First the radionuclide concentration calculations for the progeny radionuclides were checked, and then it was determined whether the dose contribution from the progeny had been added in the total dose.

TABLE 9.2 Time Dependence of Source Emission Rate and Effect on Estimated Data

RESRAD-BUILD ^a													
Concentration					Pathway Doses					Spreadsheet			
Time (yr)	Thickness (cm)	Ra-226 (pCi/g)	Pb-210 (pCi/g)	External (mrem)	Deposition (mrem)	Immersion (mrem)	Inhalation (mrem)	Radon (mrem)	Ingestion (mrem)	Ra-226 (All) (mrem)	Thickness (cm)	External (mrem)	Radon (mrem)
0	15	1.0	0.0	5.39	2920	34.7	1.88E+05	6.30E+04	7.76E+04	3.32E+05	15.0	5.34	6.29E+04
1	13.2	0.8827	0.02702	5.28	2920	34.7	2.03E+05	5.56E+04	9.01E+04	3.24E+05	13.25	5.23	5.56E+04
2	11.5	0.7656	0.04616	5.12	2920	34.7	2.18E+05	4.82E+04	1.02E+05	3.17E+05	11.494	5.08	4.82E+04
3	9.74	0.6485	0.05778	4.88	2920	34.6	2.32E+05	4.09E+04	1.14E+05	3.09E+05	9.740	4.86	4.09E+04
4	7.99	0.5316	0.06220	4.57	2920	34.6	2.45E+05	3.35E+04	1.25E+05	3.02E+05	7.987	4.55	3.35E+04
5	6.23	0.4147	0.05975	4.12	2910	34.6	2.58E+05	2.61E+04	1.36E+05	2.94E+05	6.234	4.11	2.62E+04
6	4.48	0.2979	0.05076	3.48	2910	34.6	2.71E+05	1.88E+04	1.47E+05	2.87E+05	4.481	3.48	1.88E+04
7	2.73	0.1813	0.03550	2.59	2910	34.6	2.83E+05	1.14E+04	1.57E+05	2.79E+05	2.728	2.59	1.14E+04
8	0.974	0.06474	0.01428	1.31	2910	34.6	2.95E+05	4.08E+03	1.67E+05	2.72E+05	0.9744	1.31	4.09E+03

^a Test case 16.

The radionuclide concentrations calculated by RESRAD-BUILD (case 17) were compared with the concentrations calculated by the RESRAD code (testbd.rad). For this comparison, radionuclide concentrations were calculated at time 0, 1, 3, 10, 30, 100, 300, and 1,000 years by using both codes (RESRAD and RESRAD-BUILD). In RESRAD, to avoid leaching from the contaminated zone, high distribution coefficient values were used for the principal and progeny radionuclides, and the radionuclide concentrations calculated at different times were taken from the concentration report (concent.rpt). In RESRAD-BUILD, calculations were performed with one time integration point for a volume source with no erosion. Table 9.3 presents the results of the comparison of the radionuclide concentrations obtained with the two codes. Results generated from the RESRAD-BUILD and RESRAD runs are provided in the Appendix. Concentrations for Ra-228 and its progeny, Th-228, were exactly the same in both codes. Concentrations for U-238 and its progeny — U-234, Th-230, and Ra-226 — were also the same in both codes. However, the concentrations of Pb-210 (the last progeny in the U-238 decay chain) were different at $t = 1$ and $t = 3$ years. RESRAD-BUILD gives the Pb-210 concentration as zero at $t = 1$ year, compared with the value of $1.42\text{E-}17$ given by RESRAD. At $t = 3$ years, Pb-210 concentrations were slightly different (RESRAD-BUILD $1.07\text{E-}15$, compared with $1.14\text{E-}15$ in RESRAD); at other times, values were the same in both codes. To check whether the dose contribution from the progeny was calculated properly or not, the dose at the reported concentration at later times was input as the concentration at $t = 0$ time, and the calculated doses were compared in two cases; the results were the same.

TABLE 9.3 Calculated Radionuclide Concentrations (pCi/g) at Different Times in the RESRAD-BUILD and RESRAD Codes for an Initial Parent Concentration of 1 pCi/g

Radionuclide	$t = 0$ yr	$t = 1$ yr	$t = 3$ yr	$t = 10$ yr	$t = 30$ yr	$t = 100$ yr	$t = 300$ yr	$t = 1,000$ yr
RESRAD-BUILD ^a								
U-238	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
U-234	0.0	2.84E-6	8.51E-6	2.84E-5	8.51E-5	2.84E-4	8.50E-4	2.83E-3
Th-230	0.0	1.28E-11	1.15E-10	1.28E-9	1.15E-8	1.28E-7	1.15E-6	1.27E-5
Ra-226	0.0	1.85E-15	4.97E-14	1.84E-12	4.96E-11	1.82E-9	4.81E-8	1.65E-6
Pb-210	0.0	0.0	1.07E-15	1.35E-13	9.70E-12	8.49E-10	3.57E-8	1.51E-6
Ra-228	1.0	0.8864	0.6965	0.2996	0.02688	5.82E-6	1.97E-16	0.0
Th-228	0.0	0.2853	0.5384	0.4089	0.04025	8.72E-6	2.95E-16	0.0
RESRAD ^b								
U-238	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
U-234	0.0	2.84E-6	8.51E-6	2.84E-5	8.50E-5	2.84E-4	8.50E-4	2.83E-3
Th-230	0.0	1.28E-11	1.15E-10	1.28E-9	1.15E-8	1.28E-7	1.15E-6	1.27E-5
Ra-226	0.0	1.84E-15	4.97E-14	1.84E-12	4.96E-11	1.82E-9	4.81E-8	1.65E-6
Pb-210	0.0	1.42E-17	1.14E-15	1.35E-13	9.70E-12	8.49E-10	3.57E-8	1.51E-6
Ra-228	1.0	0.8864	0.6965	0.2995	0.02688	5.82E-6	1.97E-16	0.0
Th-228	0.0	0.2853	0.5384	0.4089	0.04025	8.72E-6	2.95E-16	0.0

^a Test case 17.

^b Results from concent.rpt.

10 CONCLUSIONS

For RESRAD-BUILD verification, a Microsoft® Excel spreadsheet was prepared to perform the calculations. In some cases, computer codes such as MCNP and RESRAD also were used to benchmark RESRAD-BUILD results. Table 10.1 summarizes the findings and conclusions for the calculations investigated. Verification also confirmed that the calculated dose for all pathways, except direct external exposure, does not depend on source receptor location or the shielding characteristics as long as the source and receptor are in the same room.

The following findings/problems were identified in the process of verifying the RESRAD-BUILD code and the summary report.

- Help needs to be updated because it is not available for certain parameters (e.g., time integration points, evaluation time, flow rates between rooms, etc.).
- The nucdcf.dat file contains DCFs for ingestion, inhalation, external-surface, external-volume, and immersion pathways. It also includes half-lives, total number of gammas emitted, and the number of branching radionuclides. The values of external-surface and external-volume DCFs from this file are not used in the dose calculations; therefore, those values may be removed from the nucdcf.dat file. The values of half-lives have only three significant digits. The significant digits should be increased to match the actual half-lives.
- The last digit of the half-life is not correct for Zn-65 and Ac-227. The half-life for Zn-65 should be changed from 6.67E-01 to 6.68E-01 years, and the half-life for Ac-227 should be changed from 2.17E+01 to 2.18E+01 years.
- The inhalation DCFs for Ce-144 and Pm-147 are not correct. The Ce-144 inhalation DCF should be changed from 2.16E-04 to 3.74E-04, and the Pm-147 inhalation DCF should be changed from 2.58E-05 to 3.92E-05.
- The coeff_bd.lib file contains parameters required to compute the external pathway dose for surface and volume sources. The parameters are external DCFs for volume source, fitted coefficients of the external exposure model, collapsed gamma energies, and respective gamma fractions of radionuclides. The file has only two significant digits for some of the external exposure model parameters. The significant digits should be increased to three to get a better fit.
- In the RESRAD-BUILD summary report, the value for removable fraction at assessment times appears as 0.0, rather than the correct value.

TABLE 10.1 Conclusions on Types of Calculations Investigated

Type of Calculation	Conclusions
Input parameter check	The parameters checked included inhalation, ingestion, air submersion, and external DCFs; external exposure model parameters; and radionuclide half-lives and other decay data. Some discrepancies found in parameter values were later corrected.
Source injection rate	Excellent agreement was obtained between the RESRAD-BUILD generated results and spreadsheet calculations.
Air concentration in the room	Air concentrations for four source types were compared for one- and two-room air quality models. Excellent agreement was obtained between the RESRAD-BUILD and spreadsheet calculations.
Air particulate deposition	Air particulate deposition was computed because it is used in two pathways: external exposure due to deposited material and inadvertent ingestion directly from the deposited materials. No discrepancy was found in inadvertent pathway doses; therefore, air particulate deposition is computed correctly in the code.
Radon pathway model	The calculations checked were the radon injection rate and the radon progeny concentration. For the point, line, and area sources, there was no difference in the RESRAD-BUILD and spreadsheet calculations of the source injection rates. However, the volume source injection rates for Rn-222 and Rn-220 were different in two cases. The difference is due to the density used in the calculations. For the spreadsheet calculations, it was assumed that the particle density is input; in RESRAD-BUILD, the source bulk density was assumed. If the same density values are used in RESRAD-BUILD, the results are the same (within round-off errors) as the spreadsheet calculations. No significant differences in the RESRAD-BUILD and spreadsheet calculations were observed in radon progeny concentrations.
Tritium model for volume source	The tritium-transport model in RESRAD-BUILD for a volume source estimates the injection rate of tritiated water molecules into the indoor air from evaporation; this injection rate is then added to the source injection from erosion to calculate the total source injection. This sum source injection rate is then used to calculate air concentration, air deposition, etc. No inconsistencies between the code output and spreadsheet calculations were obtained for the injection rate of tritiated water molecules.
External exposure model	In the RESRAD-BUILD code, two direct exposure models based on the source geometry are used. The first model for area and volume sources is based on a semi-infinite slab source with corrections for geometric factors. The second model for point and line contamination is a simple dose integral method. The results of the external models were compared with those from the MCNP transport code. The comparisons were performed at different source-receptor configurations for Co-60, Mn-54, and Au-95. Good agreement (within 5%) was observed.
Different pathway doses	The different pathway doses calculated by the RESRAD-BUILD code were compared with the spreadsheet calculations. No inconsistencies between the code output and spreadsheet calculations were obtained for submersion, direct inadvertent ingestion, inadvertent ingestion of deposited materials, inhalation of airborne radioactive particulates, and tritium volume source. For inhalation of aerosol indoor radon progeny, good agreement, to within 1%, was obtained. For direct external exposure, good agreement to within 2%, and for external exposure to deposited material, agreement within 5% was observed. There was no difference in the spreadsheet calculated total receptor dose and the code calculated total receptor dose.
Time dependence in dose calculations	No significant differences in the time-integrated and the average individual pathway dose (obtained by averaging the dose over different time intervals) were obtained.

- The full file name does not print in the summary report if the file name is longer than six digits (e.g., site1111.inp appears as site1111.i).
- The way the dose is calculated for a multiwall-region volume source is confusing (e.g., the receptor was fixed at 1,1,1, a five-region volume source was selected, and the source location was changed from 0.99, 0.99, 0.99 to 1.01, 1.01, 1.01, with only the Co-60 radionuclide selected and with all default wall region parameters). The calculated dose was changed from 5.51 mrem/yr to $3.65E-5$ mrem/yr. Previously, there did not appear to be any shielding between the source and receptor, but in later cases there was a shielding thickness of 60 cm ($15 + 15 + 15 + 15 = 60$ cm from four regions was assumed.)
- Radon pathway doses appear to include the flux from both sides of the source, and the density parameter is not used properly (see Section 5 for more explanation).
- The source erosion rate should change source thickness, which should affect the calculated dose for radon and the direct external exposure pathway. To test this aspect of the code, the dose was calculated for a Ra-226 volume source with different source erosion rates. The source thickness printed in the summary report shows the correct changes due to source erosion. The calculated pathway doses appear to be correct. However, the radionuclide concentration printed in the summary report is not correct.
- Radionuclide decay and in-growth calculations in the code were tested with a U-238 source. The radionuclide concentration for Pb-210 progeny was found to be zero at $t = 1$ year (see Section 9 for a better description of the problem).
- In the RESRAD-BUILD output report, the table of contents is not comprehensive.
- Inconsistencies exist in the units used in the interface and in the report (e.g., g and gm, h and hr, etc.)
- Inconsistencies exist in the parameter names used in the interface and the report (e.g., exposure duration and total time, indoor fraction and fraction inside, wet + dry zone thickness and total thickness, water fraction available for vaporization and volatilization fraction, total porosity of contaminated material and wall total porosity, etc.)

- For the multiwall-region volume source, if the first layer is eroded, source information for the number of regions and the contaminated region is not modified in the report.
- External DCFs used in the external exposure model in the code are in units of mrem/yr per pCi/g; the DCF in the report is in units of mrem/yr per pCi/m³. The default source density in the code is 2.4 g/cm³ for the volume source, whereas the reported DCF value has a density of 1.6 g/cm³.

11 VERIFICATION LIMITATIONS AND SUGGESTIONS FOR IMPROVEMENT

Verification was limited to an initial check of input parameters and spot-checks of major portions of the code by using carefully selected radionuclides. Verification of the code interface, uncertainty analysis, and all combinations of input values was not performed in this exercise. The verification of the uncertainty analysis was documented in Kamboj et al. (2000). During the verification process, the following suggestions were made for future improvement of the RESRAD-BUILD code:

- Input and default parameter values and intermediate and complete final results should be stored and made accessible for further verification and processing;
- Input template files should be provided for typical exposure scenarios;
- Specifications on volume source regions and their relationships to the receptor should be improved; and
- An independent and comprehensive verification of the code interface and all combinations of input parameter values for all pathways should be performed.

12 REFERENCES

Briesmeister, J.F. (editor), 1993, *MCNP — A General Monte Carlo N-Particle Transport Code, Version 4A*, LA-12625, Los Alamos National Laboratory, Los Alamos, N.M.

Eckerman, K.F., and J.C. Ryman, 1993, *External Exposure to Radionuclides in Air, Water, and Soil, Exposure to Dose Coefficients for General Application*, Based on the 1987 Federal Radiation Protection Guidance, EPA 402-R-93-081, Federal Guidance Report No. 12, prepared by Oak Ridge National Laboratory, Oak Ridge, Tenn., for U.S. Environmental Protection Agency, Office of Radiation and Indoor Air, Washington, D.C.

International Commission on Radiological Protection, 1983, *Radionuclide Transformations: Energy and Intensity of Emission*, ICRP Publication 38, Annals of the ICRP, Vols. 11–13, Pergamon Press, New York, N.Y.

Kamboj, S., et al., 1998, *External Exposure Model Used in the RESRAD Code for Various Geometries of Contaminated Soil*, ANL/EAD/TM-84, Argonne National Laboratory, Argonne, Ill.

Kamboj, S., et al., 2000, *Probabilistic Dose Analysis Using Parameter Distributions Developed for RESRAD and RESRAD-BUILD Codes*, NUREG/CR-6676, ANL/EAD/TM-89, prepared by Argonne National Laboratory, Argonne, Ill., for Division of Risk Analysis and Applications, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, Washington, D.C., May.

Thibodeaux, L.J., and S.T. Hwang, 1988, “Landfarming of Petroleum Wastes — Modeling the Air Emission Problem,” *Journal of Environmental Progress* (1):42.

Yu, C., et al., 1994, *RESRAD-BUILD: A Computer Model for Analyzing the Radiological Doses Resulting from the Remediation and Occupancy of Buildings Contaminated with Radioactive Material*, ANL/EAD/LD-3, Argonne National Laboratory, Argonne, Ill., Nov.

Yu, C., et al., 2000, *Development of Probabilistic RESRAD 6.0 and RESRAD BUILD 3.0 Computer Codes*, NUREG/CR-6697, ANL/EAD/TM-98, prepared by Argonne National Laboratory, Argonne, Ill., for Division of Risk Analysis and Applications, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, Washington, D.C., Nov.

APPENDIX

**RESRAD-BUILD INPUT-OUTPUT TEST CASE FILES
AND DIAG.OUT AND SUMMARY REPORTS**

The RESRAD-BUILD input-output test case files and diag.out and summary reports for verification are provided in the companion CD-ROM to this document.

